



# Guardmaster Safety Relays

Catalog Numbers 440R-S13R2, 440R-S12R2, 440R-D22R2,  
440R-D22S2, 440R-EM4R2, 440R-EM4R2D



**Allen-Bradley**

by ROCKWELL AUTOMATION

Guardmaster®

User Manual

Original Instructions

# Important User Information

Read this document and the documents listed in the additional resources section about installation, configuration, and operation of this equipment before you install, configure, operate, or maintain this product. Users are required to familiarize themselves with installation and wiring instructions in addition to requirements of all applicable codes, laws, and standards.

Activities including installation, adjustments, putting into service, use, assembly, disassembly, and maintenance are required to be carried out by suitably trained personnel in accordance with applicable code of practice.

If this equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.

In no event will Rockwell Automation, Inc. be responsible or liable for indirect or consequential damages resulting from the use or application of this equipment.

The examples and diagrams in this manual are included solely for illustrative purposes. Because of the many variables and requirements associated with any particular installation, Rockwell Automation, Inc. cannot assume responsibility or liability for actual use based on the examples and diagrams.

No patent liability is assumed by Rockwell Automation, Inc. with respect to use of information, circuits, equipment, or software described in this manual.

Reproduction of the contents of this manual, in whole or in part, without written permission of Rockwell Automation, Inc., is prohibited.

Throughout this manual, when necessary, we use notes to make you aware of safety considerations.



**WARNING:** Identifies information about practices or circumstances that can cause an explosion in a hazardous environment, which may lead to personal injury or death, property damage, or economic loss.



**ATTENTION:** Identifies information about practices or circumstances that can lead to personal injury or death, property damage, or economic loss. Attentions help you identify a hazard, avoid a hazard, and recognize the consequence.

**IMPORTANT** Identifies information that is critical for successful application and understanding of the product.

These labels may also be on or inside the equipment to provide specific precautions.



**SHOCK HAZARD:** Labels may be on or inside the equipment, for example, a drive or motor, to alert people that dangerous voltage may be present.



**BURN HAZARD:** Labels may be on or inside the equipment, for example, a drive or motor, to alert people that surfaces may reach dangerous temperatures.



**ARC FLASH HAZARD:** Labels may be on or inside the equipment, for example, a motor control center, to alert people to potential Arc Flash. Arc Flash will cause severe injury or death. Wear proper Personal Protective Equipment (PPE). Follow ALL Regulatory requirements for safe work practices and for Personal Protective Equipment (PPE).

The following icon may appear in the text of this document.



Identifies information that is useful and can help to make a process easier to do or easier to understand.

	<b>Preface</b> .....	<b>7</b>
	Who Should Use This Manual.....	7
	Summary of Changes.....	7
	Download Firmware, AOP, EDS, and Other Files .....	7
	Definitions.....	8
	Additional Resources .....	8
	 <b>Chapter 1</b>	
<b>Overview</b>	Hardware Features.....	9
	Removable Terminal Blocks.....	9
	Status Indicators.....	9
	Multi-position Switches .....	9
	Optical Communication Bus.....	10
	CI Safety Relay (Cat. No. 440R-S13R2) .....	10
	DI Safety Relay (Cat. No. 440R-D22R2).....	10
	DIS Safety Relay (Cat. No. 440R-D22S2).....	10
	EM Safety Relay (Cat. No. 440R-EM4R2).....	10
	EMD Safety Relay (Cat. No. 440R-EM4R2D).....	10
	SI Safety Relay (Cat. No. 440R-S12R2).....	10
	 <b>Chapter 2</b>	
<b>Installation</b>	Mounting Dimensions.....	11
	DIN Rail Mounting and Removal.....	11
	Removal .....	11
	Spacing.....	11
	Removable Terminals.....	12
	Enclosure Considerations .....	12
	Help Prevent Excessive Heat.....	12
	 <b>Chapter 3</b>	
<b>Power, Ground, and Wire</b>	Wiring Requirements and Recommendation.....	13
	Wire Size .....	13
	Terminal Torque .....	13
	Terminal Assignments .....	13
	Ground the Safety Relay.....	14
	Connect a Power Supply .....	15
	Safety Inputs.....	15
	Devices with Mechanical Contacts.....	15
	Devices with OSSD Output .....	16
	Safety Mats .....	17
	Safedge Safety Edges.....	19
	Safety Outputs.....	19
	Electromechanical Outputs .....	20
	OSSD Outputs.....	20
	Surge Suppressors .....	21

	Single Wire Safety Input and Output.....	21
	Auxiliary Output.....	22
	Reset and Monitor Input.....	22
	Automatic/Manual Reset.....	23
	Monitored Reset.....	23
	Monitor with Expansion Relays.....	24
	Retriggerable Input.....	25
	Jog Input.....	25
<b>Configuration</b>	<b>Chapter 4</b>	
	Introduction.....	27
	Switch Adjustment.....	27
	DI and DIS Safety Relays.....	28
	EMD Safety Relay.....	28
	Configuration Process.....	29
	Five Steps to Configure Your GSR Safety Relay.....	29
<b>Status Indicators</b>	<b>Chapter 5</b>	
	Status Indicators During Power-up.....	31
	Status Indicators During Normal Operation.....	31
	Status Indicators During Diagnostics.....	31
<b>Pulse Testing Functions</b>	<b>Chapter 6</b>	
	Pulse Testing for Inputs.....	33
	CI Safety Relay.....	33
	DI, DIS, and SI Safety Relays.....	34
	Pulse Testing for OSSD Outputs.....	34
<b>EMD Safety Relay Timing Functions</b>	<b>Chapter 7</b>	
	Off Delay, Non-retriggerable.....	35
	Off Delay, Retriggerable.....	36
	On Delay.....	36
	Jog.....	37
<b>Internal Circuit Block Diagrams</b>	<b>Chapter 8</b>	
	CI Safety Relay (Cat. No. 440R-S13R2).....	39
	DI Safety Relay (Cat. No. 440R-D22R2).....	39
	DIS Safety Relay (Cat. No. 440R-D22S2).....	39
	EM Safety Relay (Cat. No. 440R-EM4R2).....	39
	EMD Safety Relay (Cat. No. 440R-EM4R2D).....	40
	SI Safety Relay (Cat. No. 440R-S12R2).....	40



## Application and Wiring Examples

### Chapter 9

CI Safety Relay (Cat. No. 440R-S13R2) .....	41
DI Safety Relay (Cat. No. 440R-D22R2) .....	42
DIS Safety Relay (Cat. No. 440R-D22S2) .....	43
EM Safety Relay (Cat. No. 440R-EM4R2) .....	44
EMD Safety Relay (Cat. No. 440R-EM4R2D) .....	44
SI Safety Relay (Cat. No. 440R-S12R2) .....	46

## Ethernet Communication

### Chapter 10

Webpage .....	47
Studio 5000 Logix Designer Add-on Profile (AOP) .....	48

## Troubleshooting

### Chapter 11

Tools Needed .....	49
Required Tools .....	49
Optional Tools .....	49
Follow These Steps .....	49
View the PWR/Fault Status Indicator (Step 1) .....	50
Check the Power Supply (Step 2) .....	52
Check Voltage .....	52
Verify Grounding at the Power Supply .....	52
Check Safety Device Inputs (Step 3) .....	53
Check Voltage-free Contacts .....	54
Examine Pulse Test Waveforms .....	55
Effect of OSSD Test Pulses .....	56
Detect Off Pulses .....	56
Capacitance Effect .....	57
Long Wire - Resistance Effect .....	57
Channel Simultaneity (Discrepancy) .....	58
Multiple-channel Cycling .....	58
Recovery Time .....	59
Check the Single Wire Safety Circuit (Step 4) .....	59
SWS Connections L11 and L12 .....	59
Check the Reset/Monitoring Circuit (Step 5) .....	61
Two-handed Reset Operation .....	62
Applications with OSSD Outputs and Test Pulses .....	62
Check the Safety Outputs (Step 6) .....	62
Electromechanical Output Issues .....	62
OSSD Output Issues .....	64
Auxiliary Output Issues .....	66
EMD Expansion Safety Relay B1/B2 Inputs (Step 7) .....	69
Terminal Block Removal and Replacement .....	70
Terminal Block Removal .....	70
Terminal Block Replacement .....	70
Series, Version, and Manufacturing Date Code .....	71
Current Product Label .....	71
Old Product Label .....	71

	<b>Appendix A</b>	
<b>Specifications</b>	General.....	73
	Environmental.....	73
	Safety Inputs IN, IN1, and IN2.....	74
	Reset Input .....	74
	B1 Input .....	75
	Safety Outputs.....	75
	Auxiliary Output.....	76
	Single Wire Safety (SWS) .....	76
	<b>Appendix B</b>	
<b>Regulatory Approvals</b>	Agency Certifications.....	77
	Declaration of Conformity.....	77
	CE Conformity .....	77
	UKCA Conformity.....	77
	Machine Safety Directive.....	78
	SIL Rating.....	78
	Performance Level/Category .....	78
	<b>Index .....</b>	<b>79</b>

This publication is a reference guide for the family of Guardmaster® Safety Relays (GSR). This publication describes the procedures to install, wire, and troubleshoot your relay. This publication also gives an overview of the operation of safety relays.

Who Should Use This Manual

Use this manual if your responsibilities include design, installation, programming, or troubleshooting of control systems that use safety relays, including catalog numbers:

- 440R-S13R2 (CI safety relay)
- 440R-D22R2 (DI safety relay)
- 440R-D22S2 (DIS safety relay)
- 440R-EM4R2 (EM safety relay)
- 440R-EM4R2D (EMD safety relay)
- 440R-S12R2 (SI safety relay)

You must have a basic understanding of electrical circuitry and familiarity with safety-related control systems. If you do not have this knowledge, obtain the proper training before you use this product.

Summary of Changes

This publication contains the following new or updated information. This list includes substantive updates only and is not intended to reflect all changes.

Topic	Page
Updated <a href="#">Table 12</a>	51
Updated <a href="#">Table 13</a>	52

Download Firmware, AOP, EDS, and Other Files

Download firmware, associated files (such as AOP, EDS, and DTM), and access product release notes from the Product Compatibility and Download Center at [rok.auto/pcdc](http://rok.auto/pcdc).

## Definitions

Publication [AG-7.1](#) contains a glossary of terms and abbreviations that Rockwell Automation uses to describe industrial automation systems. The following is a list of specific terms and abbreviations that are used in this manual.

**Table 1 - Definitions**

Term	Definition
N.C.	Normally Closed - An electrical contact whose normal state is in the closed position.
N.O.	Normally Open - An electrical contact whose normal state is in the open position.
OSSD	Output Signal Switching Device - Typically a pair of solid-state signals that are pulled up to the DC source supply. The signals are tested for short circuits to the DC power supply, short circuits to the DC common and shorts circuits between the two signals.
PLC	A programmable logic controller or a programmable automation controller.
Reaction time	The time between the true states of one input to the on state of the output.
Recovery time	The time that is required for the input to be in the LO state before returning to the HI state.
Reset	<p>Safety relays offer two types of reset - Monitored manual and automatic/manual.</p> <ul style="list-style-type: none"> <li>• Monitored Manual - The safety relay performs a reset function when the reset signal goes from off to on and then back to off in a prescribed time-period. The reset occurs on the trailing edge.</li> <li>• Automatic/Manual - The safety relay performs a reset function if the reset input is on. If the reset input is connected directly to 24V, the reset function is executed immediately when the inputs become closed or active. If a contact (push button or equivalent device) is used in the reset input, the reset function is executed on the leading edge of the reset signal (if the inputs are closed or active).</li> </ul>
Response time	Describes the time between the trigger of one input to the off state of the output. Throughout this manual, the safety outputs are described as turning off immediately, which means that the safety outputs turn off within the response time.
SWS	Single Wire Safety - A unique, safety-rated signal that is sent over one wire to indicate a safety status. The SWS can be used in safety systems that require Category 4, Performance Level e, per ISO 13849-1 and safety integrity level (SIL) 3, per IEC 62061 and IEC 61508. When an SWS signal is present, this publication describes this state as ACTIVE or on. This signal is also referred to as the logic link signal.

## Additional Resources

These documents contain additional information concerning related products from Rockwell Automation.

Resource	Description
Guardmaster EtherNet/IP Network Interface User Manual, publication <a href="#">440R-UM009</a>	Describes the procedures that you use to install, wire, configure, troubleshoot, and use EtherNet/IP™ modules.
Next Generation Guardmaster Safety Relay (GSR) Wiring Diagram, publication <a href="#">SAFETY-WD001</a>	Provides example wiring diagrams of various safety relay applications.
Industrial Automation Wiring and Grounding Guidelines, publication <a href="#">1770-4.1</a>	Provides general guidelines for installing a Rockwell Automation® industrial system.
Product Certifications website, <a href="http://rok.auto/certifications">rok.auto/certifications</a> .	Provides declarations of conformity, certificates, and other certification details.


You can view or download publications at [rok.auto/literature](http://rok.auto/literature).

## Overview

The Guardmaster® safety relay (GSR) family is a group of advanced general-purpose and special-purpose safety relays. This user manual addresses the CI, DI, DIS, EM, EMD, and SI safety relays from this family of relays.

## Hardware Features

Figure 1 - Safety Relays



### Removable Terminal Blocks

Each safety relay module is only 22.5 mm (0.9 in.) wide with four removable terminal blocks (two on top and two on bottom). The terminal blocks are keyed to confirm that they are installed in their proper slots. See [Terminal Block Removal and Replacement on page 70](#).

### Status Indicators

Multiple status indicators provide status and diagnostics. Under fault conditions, the PWR/Fault status indicator flashes in specific patterns to help diagnose the fault. See [Status Indicators on page 31](#) and [View the PWR/Fault Status Indicator \(Step 1\) on page 50](#) for more information.

### Multi-position Switches

Most safety relays are configured by adjusting multi-position switches to set their functionality<sup>(a)</sup>. The switches are on the front face of the safety relay so you can see the set position during, and after, configuration. During the configuration process, status indicators on the front face of the safety relay confirm the switch settings. See [Switch Adjustment on page 27](#) for more information.

(a) The EM safety relay does not require configuration.



## Optical Communication Bus

The DI, DIS, EM, EMD, and SI safety relays have an optical communications bus that delivers status and diagnostics to the catalog number 440R-ENETR EtherNet/IP™ module (not shown in [Figure 1 on page 9](#)) without additional wiring. See [Ethernet Communication on page 47](#) for more information.

Safety relays use single wire safety (SWS) signals that allow multiple safety relays to work in coordination with one another in small to medium size safety systems. The SWS feature allows safety relays to communicate the highest safety-rated control signal from one safety system to another over one wire (plus a common ground connection). The wire must be less than 30 m (98.4 ft) long.

### CI Safety Relay (Cat. No. 440R-S13R2)

The CI safety relay has one dual-channel input with three electromechanical relay outputs. The CI safety relay can be configured for automatic or monitored manual reset by adjusting the switch on the front. The CI safety relay has an SWS output, but does not support SWS input.

The CI safety relay is compatible to the MSR127 monitoring safety relay. The CI safety relay has the same number of inputs and outputs, the same width, and the same terminal locations as the MSR127 safety relay.

### DI Safety Relay (Cat. No. 440R-D22R2)

The DI safety relay has two dual-channel inputs and two electromechanical relay outputs. In addition, the DI safety relay has an SWS input and output. The DI safety relay can be set for automatic or monitored manual reset by adjusting the switch on the front panel. The configuration switch also sets the AND/OR logic that is applied to the inputs.

### DIS Safety Relay (Cat. No. 440R-D22S2)

The DIS safety relay has two dual-channel inputs and four solid-state outputs. Two of the four solid-state outputs are designed to operate with high-capacitance loads. In addition, the DIS safety relay has an SWS input and output. The DIS safety relay can be set for automatic or monitored manual reset by adjusting the switch on the front panel. The configuration switch also sets the AND/OR logic that is applied to the inputs.

### EM Safety Relay (Cat. No. 440R-EM4R2)

The EM safety relay is an expansion module with four immediately operated electromechanical relay outputs. The only input to the EM safety relay is an SWS input. The EM safety relay is designed to expand the outputs of the GSR family of host relays. The EM safety relay also has an SWS output for further expansion.

### EMD Safety Relay (Cat. No. 440R-EM4R2D)

The EMD safety relay is an expansion module with delayed electromechanical relay outputs. The EMD safety relay can be configured for one of the following functions:

- On delay
- Off delay
- Jog

The settings of the two switches on the front face of the safety relay configure the functionality and duration of the delay and jog.

The main input to the EMD safety relay is the single wire safety input. With the SWS signal, the EMD safety relay is designed to expand the outputs of the GSR family of host relays. The EMD safety relay also has an SWS output for further expansion.

An additional input is used with the jog function or to set the off delay as retriggerable. See [EMD Safety Relay Timing Functions on page 35](#) for detailed descriptions on the EMD safety relay timing functions.

### SI Safety Relay (Cat. No. 440R-S12R2)

The SI safety relay has one dual-channel input with two electromechanical relay outputs. The SI safety relay can be configured for automatic or monitored manual reset by adjusting the switch on the front. The SI safety relay also has an SWS output.


The SI safety relay is similar in functionality to the MSR126 monitoring safety relay.

## Installation

### Mounting Dimensions

All safety relays in this manual have the same dimensions.

**Figure 2 - Approximate Dimensions [mm (in.)]**




### DIN Rail Mounting and Removal

Safety relays mount onto 35 mm (1.38 in.) DIN rails: 35 x 7.5 x 1 mm (1.38 x 0.3 x 0.04 in.) (EN 50022-35x7.5).

1. Hold the top at an angle (see [Figure 3](#)).
2. Slide down until the housing catches the rail.
3. Swing the bottom down and push until the latch clips onto the rail.

**Figure 3 - DIN Rail Mounting**



### Removal

To remove a safety relay, use a screwdriver to pry the DIN rail latch downwards until it is in the unlatched position. Then, swing the module up.

### Spacing


You can mount safety relays directly next to other safety relays. When using the EtherNet/IP™ module, you must mount the safety relay within 10 mm (0.4 in.) of the neighboring module to maintain effective communication.

Maintain a space of 50.8 mm (2 in.) above, below, and in front of the safety relay for adequate ventilation.

## Removable Terminals

Safety relays have removable terminals to ease wiring and replacement.

**Figure 4 - Removable Terminals**



1. Insert the tip of a small screwdriver into the slot near the terminal screws.
2. To unlock the terminal block, rotate the screwdriver.

You can now remove the terminal block from the housing.

## Enclosure Considerations

Most applications require installation in an industrial enclosure to reduce the effects of electrical interference and environmental exposure. Pollution Degree 2 is an environment where normally only non-conductive pollution occurs with the expectation that condensation causes occasional temporary conductivity. Overvoltage Category II is the load level section of the electrical distribution system. At this level, transient voltages are controlled and do not exceed the impulse voltage capability of the product insulation.

This equipment is intended for use in a Pollution Degree 2 industrial environment, in overvoltage Category II applications (as defined in IEC 60664-1), at altitudes up to 2000 m (6562 ft) without derating. This equipment is considered Group 1, Class A industrial equipment according to IEC/CISPR 11. Without appropriate precautions, there can be difficulties with electromagnetic compatibility in residential and other environments due to conducted and radiated disturbances.

This equipment is supplied as open-type equipment. The safety relays must be mounted within an enclosure that is suitably designed for those specific environmental conditions that are present and appropriately designed to help prevent personal injury as a result of accessibility to live parts. The enclosure must have suitable flame-retardant properties to help prevent or minimize the spread of flame, in compliance with a flame spread rating of 5VA, V2, V1, V0 (or equivalent) if non-metallic. The interior of the enclosure must be accessible only by the use of a tool. Subsequent sections of this publication contain additional information regarding specific enclosure-type ratings that are required to comply with certain product safety certifications.

For more information, see publications:

- [1770-4.1](#), for additional installation requirements.
- NEMA Standard 250 and IEC 60529, as applicable, for explanations of the degrees of protection provided by different types of enclosure.

## Help Prevent Excessive Heat

For most applications, normal convective cooling keeps the safety relay within the specified operating range. Verify that the specified temperature range is maintained. Proper spacing of components within an enclosure is sufficient for heat dissipation.

In some applications, other equipment inside or outside the enclosure can produce a substantial amount of heat. In this case, place blower fans inside the enclosure to help with air circulation and to reduce "hot spots" near the controller.

Additional provisions for cooling are necessary when high ambient temperatures are encountered. Do not bring in unfiltered outside air. Place the controller in an enclosure to help protect it from a corrosive atmosphere. Harmful contaminants or dirt could cause improper operation or damage to components. In extreme cases, you must use air conditioning to help protect against heat buildup within the enclosure.

## Power, Ground, and Wire

### Wiring Requirements and Recommendation



**ATTENTION:** Before you install and wire any device, disconnect power to the system.



**ATTENTION:** Calculate the maximum possible current in each power and common wire. Observe all electrical codes that dictate the maximum current allowable for each wire size. Current above the maximum rating causes the wiring to overheat, which can cause damage.

- Allow adequate space between the I/O wire ducts and the top and bottom of the safety relays and front face to maintain an ambient temperature below the rated operating temperature of the safety relays.
- Route incoming power to the safety relay by a path separate from the device wiring. Where paths must cross, their intersection must be perpendicular.
- Do not run signal or communications wiring and power wiring in the same conduit. Route wires with different signal characteristics by separate paths.
- Separate wiring by signal type. Bundle wiring with similar electrical characteristics together.
- Separate input wiring from output wiring.
- Label wiring to all devices in the system. Use tape, shrink-tubing, or other more dependable means to label wire. Use colored insulation as well to identify wiring by signal characteristics. For example, use blue for DC wiring and red for AC wiring.

### Wire Size

Each terminal accommodates copper wire with size from 0.2...2.5 mm<sup>2</sup> (24...14 AWG). Use copper that withstands 60...75 °C (140...167 °F).


### Terminal Torque

Torque terminals to 0.4 N•m (4 lb•in).

### Terminal Assignments


Safety relays have four terminals: two on the top and two on the bottom. The X2 and X4 terminal markings apply to the rear terminals. The X1 and X3 terminals apply to the front terminals.

**Figure 5 - Terminal Identification**



The following image shows the markings on the front face of each safety relay, including the terminal and status indicator identifications.

### Figure 6 - Safety Relay Face Markings



The following table lists the terminal functions. Many of the terminals perform common functions on multiple safety relays.

### Table 2 - Terminal Assignments and Functions

Terminal	Function	Applies To
A1	+24V supply (+10%, -15%)	All
A2	24V common	All
S11	Pulse test output for Channel 1	CI, DI, DIS, and SI
S21	Pulse test output for Channel 2	CI, DI, DIS, and SI
S12	Safety input for IN1 Channel 1	CI, DI, DIS, and SI
S22	Safety input for IN1 Channel 2	CI, DI, DIS, and SI
S32	Safety input for IN2 Channel 1	DI and DIS
S34	Reset input	CI, DI, DIS, and SI
S42	Safety input for IN2 Channel 2	DI and DIS
Y32	Auxiliary non-safety output	DI, DIS, and SI
X32	Auxiliary non-safety output	EM and EMD
B1	Jog input	EMD
B2	Retrigger input	EMD
L11	Single wire safety output	All
L12	Single wire safety input	DI, DIS, EM, and EMD
13/14, 23/24	Safety outputs - electromechanical relay	CI, DI, EM, and SI
33/34	Safety outputs - electromechanical relay	CI and EM
43/44	Safety outputs - electromechanical relay	EM
14, 24	Safety Outputs - OSSD	DIS
34, 44	Safety Outputs - OSSD for capacitive loads	DIS
41/42	Auxiliary non-safety output	CI
17/18, 27/28, 37/38, 47/48	Safety Outputs, Delayed - electromechanical relay	EMD

## Ground the Safety Relay

There are no special grounding requirements. Terminal A2 must connect to the common of a 24V supply.




## Connect a Power Supply

An external 24V DC power supply source must provide power for safety relays.

To comply with the CE (European) Low Voltage Directive (LVD), a DC source compliant with safety extra low voltage (SELV) or protected extra low voltage (PELV) must power the safety relays. Bulletin 1606 power supplies are SELV and PELV-compliant.

The following image shows the power supply connections. The DI, DIS, EM, EMD, and SI safety relays have the power supply connections at the top. The CI safety relay, which is backward compatible with the MSR127 monitoring safety relay, has A1 at the top and A2 at the bottom.

**Figure 7 - Power Supply Connections**



## Safety Inputs

GSR safety relays can connect to the following devices:

- Devices with mechanical contacts
- Devices with OSSD output
- Safety mats
- Safedge™ safety edges

### Devices with Mechanical Contacts


The GSR family of safety relays can connect to safety devices that have mechanical contacts. The safety relays can accommodate either 1 N.C. or 2 N.C. circuits. The following table shows some of the devices that can connect to safety relays.

**Table 3 - Safety Devices with Mechanical Contacts**

Safety Device	Rockwell Automation Product Examples	Contact Availability
E-stop push buttons	800F, 800T	1 N.C., 2 N.C., self-monitoring
Tongue-operated interlock switches	Trojan™, MT-GD2, Cadet™, Elf™	1 N.C., 2 N.C.
Guard locking interlock switches	440G-LZ, TLS-Z, TLS-GD2, Atlas™	1 N.C., 2 N.C.
Non-contact switches with reed relays	Ferrogard™, Sipa™, magnetically coded	1 N.C., 2 N.C.
Hinge-operated interlock switches	Rotacam™, Ensign, Sprite	1 N.C., 2 N.C.
Limit switches	440P, 802T	1 N.C., 2 N.C.
Trapped key interlocks with electrical contacts	440T	1 N.C., 2 N.C.
Cable pull switches	Lifeline™	1 N.C., 2 N.C.
Enabling devices	GripSwitch	1 N.C., 2 N.C.
Interposing relays	700-HPS	1 N.C., 2 N.C.


The following image shows the typical connections for devices with 2 N.C. mechanical contacts. One side of each contact is connected to a pulse-testing outputs S11 and S21. The other side is connected to an input terminal. The CI and SI safety relays have one set of input terminals. The DI and DIS safety relays have two sets of input terminals. The DI and DIS safety relays can operate with only one device that is connected to either input or with devices that are connected to both inputs.

**Figure 8 - Example Connections to 2 N.C. Mechanical Contacts**



The following image shows the typical connections for devices with 1 N.C. mechanical contact. One side of the contact is connected to a pulse-testing output S11. The other side is connected to two input terminals. The CI and SI safety relays only have one set of input terminals. The DI and DIS safety relays have two sets of input terminals. The DI and DIS safety relays can operate with only one device that is connected or with devices that are connected to both inputs.

**Figure 9 - Example Connections to 1 N.C. Mechanical Contact**




## Devices with OSSD Output

Devices, such as the GuardShield™ safety light curtains, SafeZone™ laser scanners, SensaGuard™ interlock switch, TLS-Z and 440G-LZ guard locking switches, and Bulletin 442G Multifunction Access Box (MAB), have current-sourcing PNP semiconductor outputs (OSSD). Devices with OSSD send their own pulse-tested safety signals through their outputs. These devices do not need to connect to the safety relay pulse-testing outputs. These devices must have a common power supply reference (24V Com).

The following image shows a typical example of the connections for devices, like safety light curtains or laser scanners, with non-cascadable OSSD outputs.

**Figure 10 - Example Connections to Devices with Non-cascadable OSSD Outputs**



- OSSD1 can connect to either S12 or S22 and OSSD2 can connect to either S12 or S22.
- The safeguarding devices must have the same voltage supply reference (24V Com) as the safety relay.

The following image shows an example of a wiring configuration that includes non-cascadable and cascadable devices. The non-cascadable devices (Devices 1 and 2) must always start the cascade. Many cascadable devices (Devices 3...6 or more) can be included in the input circuit. All devices must have the same voltage supply reference (for instance, 24V Com) as the safety relay.

Examples of non-cascadable devices include GuardShield safety light curtains, SafeZone laser scanners, and safety sensors. Examples of cascadable devices include SensaGuard interlock switches, and the TLS-ZR and 440G-LZ guard locking interlock switches.




**ATTENTION:** You must consider the cumulative response time of all cascaded devices, the safety relay, and output devices to verify that the safety function is fulfilled within the required time that the risk assessment determines.

Place devices with electromechanical (EM) outputs after the non-cascadable device. You can place the EM safety relay devices anywhere in the chain after the first OSSD device.

From the perspective of the GSR safety relay, only the OSSD device closest to the safety relay (Device 3 in the following image) is of concern. The other devices with OSSD outputs do not affect the performance of the safety relay. The EM safety relay devices can suffer from masked faults, their safety rating is limited to Category 3 per ISO13849-1.

**Figure 11 - Example Connections to Device with Cascaded and Non-cascaded OSSD Devices**



GSR safety relays cannot detect short circuits of the OSSD device outputs. The PWR/Fault status indicator of your GSR safety relay remains steady green. The device with the OSSD outputs must detect short circuits of its own OSSD outputs. When detected, the device must shut off both OSSD outputs and go to a faulted state. A status indicator must inform you that the OSSD is faulted.

## Safety Mats

Guardmaster® (and similar) safety mats can connect to safety relays. These safety mats use parallel metal-plate technology. Stepping on the safety mat shorts the top metal plate to the bottom metal plate. With the proper connections, safety relays detect the presence of an object on the safety mat and turn off their outputs. With no presence on the safety mat, safety relays turn on their outputs.

When changing the function from mechanical switches or OSSDs to safety mats, GSR safety relays must go through the complete configuration process.


The following image shows the typical connections for safety mats. You notice the reverse of the wiring between a device with 2 N.C. contacts and the safety mat.

When a safety mat is used, safety relays cannot detect short circuits between the inputs or between the inputs and 24V DC. Test these conditions during validation.

**IMPORTANT** For fault detection purposes, configure GSR safety relays for monitored manual reset when connected to safety mats.

**IMPORTANT** When using safety mats, set the DI and DIS safety relays for AND logic. If you use only one safety mat, connect the second input with jumpers or to another safety device. If another safety device connects to the second input, the outputs of the safety device must be on during configuration and during power-up.

**Figure 12 – Example One Connection to Safety Mats**



Because the safety mats are parallel plates, they have a significant capacitive effect. The larger the safety mat, the more capacitance. If the capacitance is too large, the safety relay does not function properly. See [Capacitance Effect on page 57](#) for further information.




Allen-Bradley® Guardmaster MSR safety relays can be tickled by tapping on the safety mat, which generated fast cycles. This activity caused the safety relay to fault because the fast cycles violated the recovery time specification. GSR safety relays have a faster recovery time (30 ms). However, there is a small window of actuation times (around 20 ms) that can cause a GSR relay to enter a faulted state (steady red PWR/Fault indicator); a power cycle is required to clear the fault.

[Figure 13](#) shows an example where the safety mat and a device with pulse-testing OSSD outputs are connected to the DI or DIS safety relay. In this example, performance is independent of the input connection (IN1 or IN2). The devices must be connected and circuits closed during the configuration process and upon normal power-up. Upon normal power-up, the DI and DIS safety relay attempts to determine whether a safety mat is connected. During the power-up test, the DI and DIS safety relay may detect the pulse test of the OSSD device at the same time it is trying to determine if a safety mat is connected and determine that a configuration is incorrect. If this situation occurs, another power-up cycle is required.



When you combine mats with devices with OSSD outputs, the duration and period of the OSSD pulses affects the potential of a power-up fault. OSSD outputs with shorter pulse widths and longer periods contribute to fewer power-up faults.


**Figure 13 – Example Combining Safety Mats with Devices with OSSD Outputs**



## Safedge Safety Edges

Some of the Allen-Bradley Guardmaster Safedge pressure sensitive safety edges (only profiles 0110N, 0110R, and 1610N) can connect to CI, DI, DIS, and SI safety relays. The following image shows how Safedge edges are constructed of conductive rubber with two embedded wires that run the length the edge. Each wire forms a channel for the GSR safety relay. When the edge is compressed, a low resistance is created between the two channels. The Safedge edge must be constructed with four wires (two wires exit each end). See publication [440F-UM002](#) for more information on the Safedge edges.

**Figure 14 - Safedge Operating Principle**



[Figure 15](#) shows the typical wire connections. With the proper connection, GSR safety relays detect the compression of the edge and turn off their outputs. With no pressure on the edge, the GSR outputs can turn back on with a reset signal.

---

**IMPORTANT** Only use Safedge profiles 0110N, 0110R, and 1610N with the GSR safety relays.

---



---

**IMPORTANT** For fault detection purposes, configure GSR safety relays for monitored manual reset when connected to Safedge safety edges.

---




---

**IMPORTANT** When using safety edges, set the DI and DIS safety relays for AND logic. If only one edge is used, the second input must either connect with jumpers or to another safety device. If another safety device is connected to the second input, the outputs of the safety device must be on during configuration and during power-up.

---

**Figure 15 - Example Connections to Safety Edges**



## Safety Outputs

GSR safety relays have two types of outputs:

- Electromechanical (CI, DI, EM, EMD, and SI safety relays)
- OSSD (DIS safety relay)


To extend the operating life of the safety relays, surge suppression is required.



## Electromechanical Outputs

Internally, the CI, DI, EM, EMD, and SI safety relays have two positive-guided safety relays that are connected in series to form the safety outputs. One side of the contact must connect to a voltage supply (see [Specifications on page 73](#) for appropriate ratings). The other side of the contact must connect to a load.

**Figure 16 – Electromechanical Output Connections**



## OSSD Outputs


The DIS safety relay has OSSD safety outputs on terminals 14, 24, 34 and 44. Output terminals 14 and 24 are pulse tested and can switch loads up to 1.5 A. They can only tolerate a load capacitance up to 1.6  $\mu\text{F}$ . Terminals 34 and 44 have a series diode and can switch loads up to 0.5 A. They can tolerate a load capacitance up to 9  $\mu\text{F}$ . Terminals 34 and 44 are also pulse tested, but these pulse tests are ignored as they are not used for short-circuit detection. These terminals are intended for devices with high capacitance. For example, use terminals 34 and 44 when connecting to the Enable input of the PowerFlex® 70 drive and the Safe Torque Off inputs of the PowerFlex and Kinetix® drives.

The pulse-tested outputs check for short circuits between the following:

- Each terminal.
- Each terminal and the 24V supply.
- Each terminal and 24V common. The load must connect to the same voltage reference as terminal A2.

The load must connect to the same voltage reference as terminal A2. All four OSSD outputs are short-circuit protected.

**Figure 17 – OSSD Output Connections**



## Surge Suppressors


Because of the potentially high current surges that occur when switching inductive load devices, such as motor starters and solenoids, the use of surge suppression to help protect and extend the operating life of the safety relays is required. By adding a suppression device directly across the coil of an inductive device, you prolong the life of the outputs. You also reduce the effects of voltage transients and electrical noise from radiating into adjacent systems.

The following image shows an output with a suppression device. We recommend that you locate the suppression device as close as possible to the load device.

For outputs that use 24V DC, we recommend 1N4001 (50V reverse voltage) to 1N4007 (1000V reverse voltage) diodes for surge suppression for the OSSD safety outputs. The diode must connect as close as possible to the load coil.

For outputs that use 120V AC or 240V AC, we recommend metal oxide varistors.

**Figure 18 - Surge Suppressors**



Example surge suppressors include the following catalog numbers:

- 100-FSD250 for Bulletin 100S contactors
- 1492-LD4DF terminal block with built-in 1N4007 diode
- 1492-JD3SS terminal block with built-in varistor

## Single Wire Safety Input and Output

The Single Wire Safety (SWS) feature allows a safety relay to expand the safety function to additional safety relays using one wire, provided all safety relays have the same voltage supply reference.

The CI and SI safety relays only have SWS outputs (terminal L11). The DI, DIS, EM, and EMD safety relays have both SWS inputs (terminal L12) and SWS outputs (terminal L11).

There are many variations and combinations of series and parallel connections of the SWS. Each L11 terminal (except the EM safety relay) can connect to up to ten L12 terminals. The EM safety relay simply passes the input SWS signal at L12 directly to its L11 terminal, therefore, it has no additional fanout capability.

---

**IMPORTANT** Do not connect two or more L11 terminals together.

---


The following image shows an example wiring diagram with SWS input from a DI safety relay and SWS output connection to an EM safety relay in parallel with a DIS safety relay. The safety relays must have a common power reference (24V common). In this example, the safety function that is started by the CI or SI safety relay is expanded to the DI safety relay. The safety functions monitored by the DI safety relay are expanded to the EM and DIS safety relays. The safety functions monitored by the DIS safety relay are expanded to the EMD safety relay.



**ATTENTION:** You must consider the additional response time of each SWS connection when calculating the safety distance. See [Specifications on page 73](#) for the response time for each safety relay.


---

Figure 19 - Example SWS Connections



The following image shows the characteristics of the SWS signal when it is active. It starts with a 1 ms pulse, followed 700  $\mu$ s later by a 500  $\mu$ s pulse. This waveform is repeated every 4 ms. When inactive, the SWS is 0V.

Figure 20 - SWS Waveform – Terminals L11 and L12



## Auxiliary Output

Each safety relay has an auxiliary output. The auxiliary output is not a safety rated output; it is a low current output that is designed to indicate that the safety output status is off. The auxiliary output is in the opposite state of the safety outputs. When the safety outputs are on, the auxiliary output is off. When the safety outputs are off, the auxiliary output is on.

When the EM and EMD safety relays are in a nonrecoverable faulted state, the auxiliary outputs are in an off state because the auxiliary outputs are often used as the source of the monitoring circuit. If the EM or EMD safety relays are faulted, the safety system must not reset until the nonrecoverable fault is corrected.

The DI, DIS, EM, EMD, and SI safety relays have a solid-state transistor auxiliary output. The CI safety relay has an electromechanical output. The following table summarizes the terminal connections of the auxiliary output.

Table 4 - Auxiliary Outputs

Safety Relay	Type of Output	Terminal Connections
CI	Electromechanical	41/42
DI, DIS, SI	Transistor	Y32
EM, EMD	Transistor	X32

## Reset and Monitor Input


The CI, DI, DIS, and SI safety relays have a reset/monitoring input (terminal S34). The expansion safety relays (EM and EMD) do not have a reset input.

You can configure the reset action for either automatic or manual reset. When the safety relay is configured for automatic reset, the safety relay outputs turn on as soon as the safety inputs are closed if terminal 34 is connected to 24V. If a normally open switch is placed in the circuit, the reset function occurs on the leading edge (when the switch is pressed).

When the safety relay is configured for manual reset, the safety relay outputs turn on after the inputs are closed and then the reset input is cycled from off to on and then back off again.

Monitor external devices, like safety control relays and safety contactors, by adding N.C. contacts in series with the reset signal. The following image shows typical reset/monitoring circuits.

Figure 21 - Typical Reset/Monitoring Circuits



Circuit	Description
1	In automatic/manual reset, you can make a direct connection to 24V DC.
2	Output devices are monitored with their normally closed contacts. Only use this circuit in automatic/manual reset.
3	An N.O. push button is used. You can configure the safety relay for automatic/manual reset or monitored manual reset.
4	Output devices are monitored along with an N.O. push button. You can configure the safety relay for automatic/manual reset or monitored manual reset.
5	An EM or EMD expansion safety relay is used to supply the voltage to terminal S34. This circuit can also contain feedback contacts and a Reset push button, similar to circuits 2, 3, and 4.
6	A PLC is used to generate the reset signal. You can configure the GSR safety relay for either automatic/manual or monitored manual reset.

## Automatic/Manual Reset


Use automatic reset when the risk assessment does not require additional manual intervention to reset the safety system. Automatic reset is often used with partial body access or where an additional control is implemented in the machine control system to start the hazardous portion of the machine after the safety inputs are closed.

When automatic reset is desired, the S34 input must connect to 24V DC. The following image shows three possibilities:

- A direct connection
- A connection through some monitoring contacts
- A connection through an N.O. push button.

You can combine the connection through a monitoring contact and push button. When a push button is used, the reset occurs when the circuit is closed (not when it is released).

Figure 22 - Automatic/Manual Reset Connections




## Monitored Reset

Monitored reset requires a specific signal to turn on the safety outputs. The safety inputs and single wire safety input (if used) must close before the reset. The reset signal must cycle from

0V to 24V and back to 0V within a duration of 250...3000 ms, as shown in the following image. The reset occurs on the trailing edge. If the reset signal is too short or too long, the reset function is not executed and you can try again.

Use the monitored reset in applications that have full-body access to the hazard. You can also use the monitored reset in applications that require partial body access.

Figure 23 – Monitored Reset Signal Duration



You can create the signal with a momentary push button or programmatically create the signal with a logic controller. The following image shows example wire connections for the reset. The schematic also shows an example monitoring the mechanically linked, normally closed contacts of two contactors.



 When using a PLC to generate the reset signal, set the duration to 260...2990 ms for a more reliable reset.


Figure 24 – Monitored Reset Connections



### Monitor with Expansion Relays

Monitoring of the expansion relays is recommended. This feature is especially useful when the expansion relay is turning on loads (for example, solenoid-operated valves) that do not have monitoring contacts. The auxiliary output of the expansion relay must be the 24V DC source of the reset and monitoring input. The following image shows an example of the connections for a monitored reset with additional contactor monitoring. You can also use this type of connection for automatic reset applications.

Figure 25 – Monitor Expansion Relay





## Retriggerable Input

The B1 and B2 inputs determine the type of timing function.

- B1 and B2 open: Off-delay non-retriggerable or on-delay
- B1 connected to B2: Off-delay retriggerable
- B1 connected to 24V DC: Jog

The EMD safety relay has a retriggerable input. Retriggerable operation only works in off-delay applications. Retriggerable operation is accomplished by connecting a jumper from terminal B1 to B2. The following table describes the off-delay operation.

**Table 5 - Retriggerable Operation**

Configuration	Jumper	Action
Retriggerable	B1-B2	If the safety input is triggered and cleared within the duration of the time delay, then the timing request is ignored and the safety output contacts remain closed. The B1 status indicator is on.
Non-retriggerable	None	The full-time delay lapses and the safety output contacts open before the safety relay can reset. The B1 status indicator is off.

## Jog Input

When the EMD safety relay is configured for the Jog functions, terminal B1 must connect to +24V DC.

**Notes:**

# Configuration

## Introduction

The multi-position, rotary switches on the front face of a GSR safety relay determine its functionality. The configuration method of a GSR safety relay must provide means to help protect against manipulation and maintain the integrity of the configuration.

The rotary switches accommodate a small screwdriver to turn the switch to the desired switch position. The configuration procedure implies a willing action by the person who configures the safety function to prove that the person is conscious and able to perform this task. Therefore, GSR safety relays require a procedure of turning a switch to position [0] to start the Configuration mode and then turn to the position desired.

The status indicators on the front panel provide continuous feedback by flashing the switch positions. Power cycling the device completes the Configuration mode and the device enters operation.

## Switch Adjustment

These safety relays have multi-position switches on their front face. Use a small screwdriver to set the switches to the desired setting.



 Make note of the mechanical stop location.

Figure 26 - Configuration Switch Adjustment



**IMPORTANT** Adjust the switches gently and do not turn past the mechanical stops.

CI and SI safety relays have a three-position Reset switch. This switch determines whether the safety relay uses a monitored manual reset or an automatic/manual switch (see [Definitions on page 8](#)).

Table 6 - CI and SI Safety Relay Logic Switch

Position	Function
0	Start configuration
MM	Monitored manual reset
AM	Automatic/manual reset

## DI and DIS Safety Relays

The DI and DIS safety relays have a 10-position switch and use only the first nine positions. As shown in the following table, this switch configures the safety relay for its reset and logic functionality.

Table 7 - DI and DIS Safety Relay Logic Switch

Position	Reset	Function
0	Not applicable	Start configuration
1	Monitored manual	(IN1 OR IN2) OR L12
2		(IN1 AND IN2) OR L12
3		(IN1 OR IN2) AND L12
4		(IN1 AND IN2) AND L12
5	Automatic/manual	(IN1 OR IN2) OR L12
6		(IN1 AND IN2) OR L12
7		(IN1 OR IN2) AND L12
8		(IN1 AND IN2) AND L12

**Example 1:** Logic setting 1 or 5: If any of the inputs (IN1, IN2, or L12) are on, then the safety relay refers to the reset logic.

**Example 2:** Logic setting 4 or 8: If all three of the inputs (IN1, IN2, and L12) are on, then the safety relay refers to the reset logic.

## EMD Safety Relay

The EMD safety relay has two switches. The combination of the switch settings determines the functionality and the duration. During configuration, the Time switch determines the duration of the Range switch. The following image and table show the setting options for the Range and Time switch.

- With the Time switch set to 1 at the start of the configuration process, the duration of the Range switch is the shorter range.
- With the Time switch set to 10 at the start of the configuration process, the duration of the Range switch is the longer range.

Figure 27 - EMD Safety Relay Range and Time




Table 8 - EMD Safety Relay Range and Time Settings

Position	Range			Time
	Function	Range (Time 1) [s]	Range (Time 10) [s]	
0	Start configuration	—	—	—
1	Off delay	0.1...1	10...100	10
2		1...10	100...1000	20
3		3...30	300...3000	30
4		30...300	—	40
5	On delay	0.3...3	30...300	50
6		3...30	300...3000	60
7		30...300	—	70
8	Jogging	1...10	100...1000	80
9		3...30	300...3000	90
10	—	—	—	100

**Example 1:** The range setting is 3 (starting with the Time set to 1), and the Time setting is 5. Then the off-delay is:  $30\text{ s} * 50\% = 15\text{ seconds}$

**Example 2:** The range setting is 6 (starting with the Time set to 10), and the Time setting is 1. Then the on-delay is:  $3000\text{ s} * 10\% = 300\text{ seconds}$

## Configuration Process

Configuration is a five-step process. The process requires the wiring to be completed and the inputs closed. During the configuration process, GSR safety relays send out test pulses to determine how it is wired and then configures the internal parameters to match the application.

### Five Steps to Configure Your GSR Safety Relay

1. With the power off, prepare the switches.

Safety Relay	Action
DI/DIS	Set the Logic switch to position 0.
CI/SI	Set the Reset switch to position 0
EMD expansion safety relay	Set the Range switch to position 0 and set the Time switch to 1 (short timing range) or 10 (long timing range).
EM expansion safety relay	No switches. No action necessary.

2. Apply power.

After a short wait, the PWR/Fault status indicator flashes red continuously at a 1 Hz rate (0.5 s on, 0.5 s off). The prior configuration in the EEPROM is erased, and the device is now prepared for a new configuration.

3. Adjust the Logic, Reset, Time, and Range switch settings as needed for your application.



You can change (or readjust) the switch settings during [step 3](#) and [step 4](#). The power status indicator momentarily flashes red again.

4. Verify the settings by counting the flash rates of the status indicators.
- The following table shows the status indicator that flashes for the corresponding switch setting for each safety relay.

Table 9 - Configuration Confirmation

Safety Relay	Status Indicator	Switch Setting
CI	IN	Reset
DI	IN 1	Logic
DIS	IN 1	Logic
EMD	B1	Range
	Logic IN	Time
SI	IN	Reset

The following image shows an example of the flashing patterns for the EMD expansion safety relay. The status indicators flash for 0.5 seconds to indicate the switch settings. The number of flashes is equal to the switch setting. The flashing pattern repeats after a 2 second pause.

Figure 28 - EMD Expansion Safety Relay Status Indicators Flashing in Configuration Mode

B1 - Indicates that the RANGE Switch is set to 3.



Logic IN - Indicates that the TIME Switch is set to 4



5. Cycle the power to store the settings.
- After power-up, the current switch settings are compared to the values in the EEPROM (makes sure that the switches were not changed while power was off), and the input and output circuits are checked. Upon successful completion of the internal checks, the safety relays are ready for operation.

**IMPORTANT**

To keep your GSR safety relay from permanently faulting, complete the configuration process by cycling the safety relay power within 5 minutes of rotary switch configuration.

## Status Indicators

### Status Indicators During Power-up

### Status Indicators During Normal Operation

The status indicators provide operating status and diagnostic information.

Table 10 - Status Indicators (Normal Operation)

Status Indicator	Models	State	Description
PWR/Fault	All	Steady green	Normal operation.
		Flashing red	Nonrecoverable fault. See <a href="#">Table 12 on page 51</a> . Correct fault and cycle power.
		Green with flashing red	Recoverable fault. See <a href="#">Table 13 on page 52</a> . Correct fault and press Reset.
		Steady red	Internal fault. Cycle power.
IN or IN 1	CI, DI, DIS, SI	On	Input circuits at S12 and S22 are closed.
		Off	Input circuits at S12 and S22 are open.
IN 2	DI, DIS	On	Input circuits at S32 and S42 are closed.
		Off	Input circuits at S32 and S42 are open.
B1	EMD	On	Input circuit at B1 is closed.
		Off	Input circuit at B1 is open.
LOGIC IN	DI, DIS, EM, EMD	On	Logic IN signal (Single Wire Safety) at L12 is on.
		Off	Logic IN signal at L12 is off.
	EMD	Flashing	Timing cycle is in process.
OUT	All	On	L11 is on.
		Off	L11 is off.
	CI	On	13/14, 23/24, 33/34 closed (41/42 open).
		Off	13/14, 23/24, 33/34 open (41/42 closed).
		Flashing	Safety input is closed, waiting for the reset input.
	DI	On	13/14, 23/24 closed (Y32 Off).
		Off	13/14, 23/24 open (Y32 On).
		Flashing	Safety inputs are closed, waiting for the reset input.
	DIS	On	14, 24, 34, 44 On (Y32 Off).
		Off	14, 24, 34, 44 Off (Y32 On).
		Flashing	Safety inputs are closed, waiting for the reset input.
	EM	On	13/14, 23/24, 33/34, 43/44 closed (X32 Off).
		Off	13/14, 23/24, 33/34, 43/44 open (X32 On).
	EMD	On	17/18, 27/28, 37/38, 47/48 closed (X32 Off).
		Off	17/18, 27/28, 37/38, 47/48 open (X32 On).
	SI	On	13/14, 23/24 closed (Y32 Off).
		Off	13/14, 23/24 open (Y32 On).
		Flashing	Safety input is closed, waiting for reset input.

### Status Indicators During Diagnostics

See the following tables:

Table	Page
PWR/Fault Status Indicator Is Steady Red	<a href="#">50</a>
PWR/Fault Status Indicator Is Flashing Red	<a href="#">51</a>
PWR/Fault Status Indicator Is Green with Flashing Red	<a href="#">52</a>



**Notes:**

## Pulse Testing Functions

Safety relays use pulse testing of inputs and outputs to verify that the safety function is performed when called upon. Pulse testing for the inputs must be used with devices with mechanical contacts like E-stop push buttons, tongue operated interlock switches, and limit switches. The pulse testing cannot be turned on or off and cannot be changed.

The test pulses are used to detect three short circuit conditions:

- Between the input terminals and +24V.
- Between the input terminals and 24V common.
- Between the two input terminals.

### Pulse Testing for Inputs

Pulse testing for the inputs is generated on terminals S11 and S21 of the CI, DI, DIS, and SI safety relays. The EM and EMD safety relays do not use pulse testing.

---


**IMPORTANT** The pulse test sequences are provided for informational purposes. All timing values are approximate.

---

### CI Safety Relay

The pulse testing that is associated with the CI safety relay is shown in the following image. The pulse widths are 2.5 ms wide. The pulse testing on S11 and S21 is offset by 1 ms. The pulses are repeated every 14 ms.

**Figure 29 - Pulse Test Sequence for CI Safety Relay**




When using a digital multimeter, S11 measures approximately 19V and S21 measures approximately 19V when the supply voltage to A1 is 24V DC and the input circuits are open.

At the minimum-rated input on voltage (11V), a DC multimeter reads approximately 8.9V DC at S12 and S22.

DI, DIS, and SI Safety Relays

The pulse test sequence for the DI, DIS, and SI safety relays are shown in the following image. The sequence is repeated every 12.2 ms.

Figure 30 - Pulse Test Sequence for DI, DIS, and SI Safety Relays




When using a digital voltmeter, S11 measures approximately 14V DC and S21 measures approximately 18V DC when the supply voltage to A1 is 24V DC.

Pulse Testing for OSSD Outputs


The DIS safety relay has OSSD transistor outputs. One main transistor supplies current to four individual transistors (see the following image). When the main transistor is pulse tested, the pulse appears on all outputs. When the individual transistors are tested, the pulse only appears on that transistor.

Figure 31 - Output Transistor Arrangement



The pulse test pattern is shown in the following image. The pulse widths vary from 50...150  $\mu$ s. The pulse pattern on terminal 14 is identical to terminal 34, and the pulse pattern on 24 is identical to 44. The pattern is repeated every 3.371 seconds.

Figure 32 - OSSD Output Test Pulses on DIS Safety Relay



Although pulse tests appear on terminals 34 and 44, the DIS safety relay does not detect faults from A1 to 34, 44 or between 34 and 44 when the outputs are on.

## EMD Safety Relay Timing Functions

The EMD safety relay has three functions that use timing:

- Off delay
- On delay
- Jog


The off-delay timing depends on whether the function is retriggerable.

During the timing cycle, the Logic IN status indicator flashes.

### Off Delay, Non-retriggerable

With input B1 open, the off-delay function is not retriggerable. The off-delay timer starts when the logic link signal at terminal L12 turns off. Once started, the off-delay timer runs for its full duration. The following image shows three cases of the timing sequences that can occur with this configuration.

Figure 33 - Off-delay, Non-retriggerable Timing Diagram



#### Case 1

Sequence	Description
1	The logic link signal at terminal L12 turns on and the safety outputs turn on immediately (that is, within the specified reaction time).
2	The logic link signal turns off and the off-delay timer starts.
3	The off-delay time has elapsed, and the safety outputs turn off.

#### Case 2

Sequence	Description
4	The logic link signal at terminal L12 turns on, and the safety outputs turn on within the specified reaction time.
5	The logic link signal turns off and the off-delay timer starts.
6	During off-delay time, the logic link signal turns off. A recoverable fault occurs. The PWR/Fault status indicator is green and flashing red four times.
7	The off-delay time has elapsed, and the safety outputs turn off.
8	The logic link signal turns off.
9	Shortly after the logic link turns off, the fault is automatically cleared. The PWR/Fault status indicator is steady green.

#### Case 3

Sequence	Description
10	The logic link signal at terminal L12 turns on, and the safety outputs turn on within the specified reaction time.
11	The logic link signal turns off and the off-delay timer starts.


Case 3 (Continued)

Sequence	Description
12	During off-delay time, the logic link signal turns off. A recoverable fault occurs. The PWR/Fault status indicator is green and flashing red four times.
13	The logic link turns back on. The fault continues to exist.
14	The off-delay time has elapsed; the safety outputs turn off; and the fault is automatically cleared.

Off Delay, Retriggerable

To use the retriggerable off-delay function, input terminal B1 must connect to terminal B2 before the configuration process. The off-delay timer starts when the logic link signal at terminal L12 turns off. During the timing cycle, the off-delay timer is automatically reset to zero when the logic link turns back on. The following image shows two cases of the timing sequences that can occur with this configuration.

Figure 34 - Off-delay, Retriggerable Timing Diagram



Case 1

Sequence	Description
1	The logic link signal at terminal L12 turns on, and the safety outputs turn on immediately (that is, within the specified reaction time)
2	The logic link signal turns off, and the off-delay timer starts.
3	The off-delay time has elapsed, and the safety outputs turn off.


Case 2

Sequence	Description
4	The logic link signal at terminal L12 turns on, and the safety outputs turn on within the specified reaction time.
5	The logic link signal turns off, and the off-delay timer starts.
6	During off-delay time, the logic link signal turns on. The off-delay timer is set back to zero, and the safety outputs remain on. No fault occurs.
7	The logic link signal turns off, and the off-delay timer starts.
8	The off-delay time has elapsed, and the safety outputs turn off.

On Delay

To use the on-delay function, terminal B1 must be an open connection. The on-delay timer starts when the logic link signal at terminal L12 turns on. The safety outputs turn on after the delay time expires and remain on until the logic link signal turns off. If the logic link signal turns off during the timing cycle, the safety outputs turn off immediately. The following image shows two cases of the timing sequences that can occur with this configuration.

Figure 35 - On-delay Timing Diagram



Case 1

Sequence	Description
1	The logic link signal at terminal L12 turns on, and the on-delay timer starts.
2	The on-delay timer elapses, and the safety outputs turn on.
3	When the logic link signal turns off, the safety outputs turn off.


**Case 2**

Sequence	Description
4	The logic link signal at terminal L12 turns on, and the on-delay timer starts.
5	The logic link signal turns off before the on-delay time elapses. The on-delay timer is reset to zero. No fault occurs.
6	After a brief interruption (even as short as 100 ms), the logic link signal turns back on. The on-delay timer starts from zero.
7	The on-delay timer elapses, and the safety outputs turn on.
8	When the logic link signal turns off, the safety outputs turn off.

**Jog**

The jog function has two timers: an on-timer and an off-timer. The Range and Time switch settings set the on-timer during configuration. The on-timer starts when both the B1 terminal is connected to 24V DC and the logic link signal at terminal L12 is on. The order in which these two signals turn on is not relevant. When both signals are on, the safety outputs turn on during the on-timer. After the on-timer expires, the safety outputs turn off and the off-timer starts. The off-timer is fixed at 500 ms. After the safety outputs turn off, they remain off until the off-timer elapses. Then the jog can be restarted. The following image shows three cases of timing sequences.

During the on-timer cycle, the Logic IN status indicator flashes at a 1 Hz rate. During the off-timer cycle, the Logic IN status indicator flashes at an 8 Hz rate.

**Figure 36 - Jog Timing Diagram****Case 1**

Sequence	Description
1	The logic link signal at terminal L12 turns on.
2	The B1 terminal turns on. The jog on-timer starts, and the safety outputs turn on.
3	The jog on-timer elapses, and the safety outputs turn off. The jog off-timer starts.
4	After 500 ms, the jog function is complete.
5	The B1 inputs turn off.
6	With the logic link input still on, the jog function is repeated when the B1 signal turns on.
7	The logic link signal turns off.



The L12 and B1 signals are interchangeable. The B1 signal can remain on and the L12 turns on and off to execute the jog function.

**Case 2**

Sequence	Description
8	The B1 signal turns on before the logic link signal.
9	The logic link signal turns on. The jog on-timer starts, and the safety outputs turn on.
10	The B1 signal turns off before on-timer elapses. The safety outputs turn off immediately and the off-timer starts.
11	The off-timer elapses. The logic link signal turns off to end Case 2.



The L12 and B1 signals are interchangeable. If the B1 signal remains on and the L12 turns off before the on-timer elapses, the safety outputs turn off immediately.

Case 3

Sequence	Description
12	The logic link signal at terminal L12 is on. The B1 signal turns on. The jog on-timer starts, and the safety outputs turn on
13	The on-timer elapses and the safety outputs turn off. The off-timer starts.
14	During the off-timer cycle, the B1 signal is turned off and then quickly back on. The safety outputs remain off
15	The B1 signal must turn off before a new jog cycle can begin.



The L12 and B1 signals are interchangeable. At least one of these two signals must remain off throughout the off-timer cycle before a new jog cycle begins.




## Internal Circuit Block Diagrams

The figures in this chapter show the internal circuit block diagrams of each safety relay.


### CI Safety Relay (Cat. No. 440R-S13R2)

Figure 37 - CI Safety Relay Circuit Diagram




### DI Safety Relay (Cat. No. 440R-D22R2)

Figure 38 - DI Safety Relay Circuit Diagram




### DIS Safety Relay (Cat. No. 440R-D22S2)

Figure 39 - DIS Safety Relay Circuit Diagram




### EM Safety Relay (Cat. No. 440R-EM4R2)

Figure 40 - EM Safety Relay Circuit Diagram




EMD Safety Relay  
(Cat. No. 440R-EM4R2D)

Figure 41 - EMD Safety Relay Circuit Diagram



SI Safety Relay  
(Cat. No. 440R-S12R2)

Figure 42 - SI Safety Relay Circuit Diagram



## Application and Wiring Examples


The application and wiring examples in this chapter show you how to put the inputs and outputs together to create an operating safety system. These circuit diagrams are examples; many features are interchangeable between safety relays.

Publication [SAFETY-WD001](#) provides additional application and wiring diagrams.

### CI Safety Relay (Cat. No. 440R-S13R2)


In the following image, the CI safety relay is monitoring a device (an E-stop push button) with mechanically operated contacts. The CI safety relay is configured for monitored manual (MM) reset. The output turns on if the E-stop is released and the Reset push button is pressed and released between 0.25...3 seconds. The CI safety relay monitors the status of the two output contactors, K1 and K2. If either fails to close their N.C. contacts, the CI safety relay does not reset. An auxiliary signal, terminals 41/42, is sent to the PLC when the E-stop is pressed.

**Figure 43 - Mechanical Contacts with Monitored Manual Reset**



The following image shows a CI safety relay monitoring a safety light curtain with two OSSD outputs. The CI safety relay is set to automatic/manual reset (AM). The auxiliary signal (terminals 41/41) informs the PLC that the safety system is off or on. The CI safety relay outputs connect to AC voltage loads. When the CI safety relay is on, the PLC can then turn on the K1 and K2 contactors.


**Figure 44 - With Device Using OSSD Outputs, Automatic Reset, AC Load Voltage**



## DI Safety Relay (Cat. No. 440R-D22R2)


The DI safety relay in the following image monitors two devices having mechanical contacts and is set for monitored manual reset. With the two devices closed, the operator presses the Reset button to energize contactors K1 and K2. The DI safety relay verifies that contactors K1 and K2 are off by monitoring the mechanically linked normally closed contacts in the reset circuit. When the DI safety relay is off, the auxiliary signal at terminal Y32 turns on and reports the status to a PLC.

**Figure 45 - With Two Devices with Mechanical Contacts and Monitored Manual Reset**



In the following image, a DI safety relay monitors a safety mat and non-contact interlock with OSSD outputs. Make note of the specific wiring for the safety mat. Also, during configuration and for each power-up, the safety mat must be clear and the interlock closed. The DI safety relay must be configured for AND logic for the two inputs. The DI safety relay logic setting is 6: (IN1 AND IN2) OR L12 with automatic reset. The DI safety relay verifies that contactors K1 and K2 are off by monitoring the mechanically linked normally closed contacts in the S34 circuit. When the DI safety relay is off, the auxiliary signal at terminal Y32 turns on and reports the status to a PLC. Per ISO 13856-1, safety mat applications require a manual reset function. For fault detection purposes, all GSR safety relays used for safety mat control must be configured for monitored manual reset.


**Figure 46 - With a Safety Mat and Device with OSSD Outputs, Monitored Manual Reset, AC Loads**



## DIS Safety Relay (Cat. No. 440R-D22S2)


The following image shows the DIS safety relay with only one device. The DIS and DI safety relays can monitor one device by configuring the safety relay for OR logic. The DIS safety relay logic setting is 1: (IN1 OR IN2) OR L12 with monitored manual reset. The second input (terminals S32 and S42) requires no connection. With solid-state outputs, the contactors K1 and K2 must be 24V DC powered coils. The DIS safety relay verifies that contactors K1 and K2 are off by monitoring the mechanically linked normally closed contacts in the S34 circuit. When the DIS safety relay is off, the auxiliary signal at terminal Y32 turns on and reports the status to a PLC.

**Figure 47 - Single Input, Monitored Reset**



The DIS safety relay monitors two devices with OSSD outputs in the following image. The DIS safety relay logic setting is 6: (IN1 AND IN2) OR L12 with automatic reset. The output terminals 34 and 44 are designed to tolerate higher capacitance loads (but lower resistive load) as compared to terminals 14 and 24.


**Figure 48 - High Capacitive Load**



## EM Safety Relay (Cat. No. 440R-EM4R2)

The EM safety relay in the following image expands the number of outputs of the DI safety relay. The single wire safety signal from terminal L11 to L12 instructs the EM safety relay to turn on and off. The EM safety relay outputs mimic the DI safety relay outputs. The DI safety relay monitors contactors K1...K6 and the status of the EM safety relay by sourcing the reset signal from the X32 terminal on the EM safety relay.

**Figure 49 - Expansion of Immediate Safety Outputs**




## EMD Safety Relay (Cat. No. 440R-EM4R2D)

The EMD safety relay in the following image is configured for a 5 second off-delay. The single wire safety signal from terminals L11 to L12 instructs the EMD safety relay to turn on and off. When the E-stop is pressed, the CI safety relay turns off immediately and the EMD safety relay turns off 5 seconds later. The CI safety relay monitors contactors K1...K6 and the status of the EMD safety relay by sourcing the reset signal from the X32 terminal on the EMD safety relay.

In this example, the jumper from B1 to B2 makes the EMD safety relay retriggerable. If the E-stop is released and the reset is pressed within the 5 second delay time, the outputs of the EMD safety relay do not turn off because the internal timer is retriggered.


**Figure 50 - EMD Safety Relay - Off Delay**



The following image shows the EMD safety relay that is configured for a 2.1 second on-delay. The single wire safety signal from terminals L11 to L12 instructs the EMD safety relay to turn on and off. When the Reset button is pressed, the DIS safety relay outputs turn on immediately. After a 2.1 second delay, the EMD safety relay outputs turn on.

The DIS safety relay monitors contactors K1...K4 and the status of the EMD safety relay by sourcing the reset signal from the X32 terminal on the EMD safety relay.


**Figure 51 - EMD Safety Relay - On Delay**



The EMD safety relay in the following image is configured for a maximum of a 100 second jog. The single wire safety signal from terminals L11 to L12 enables the EMD safety relay when the safety gate is closed and the SI safety relay is reset. When enabled, press and hold closed the Jog switch to turn on the EMD safety relay outputs. If the Jog button is released before the 100 second time, the EMD safety relay outputs turn off. If the Jog button is held longer than 100 seconds, the EMD safety relay outputs only turn on for 100 seconds.

For most applications, the jog switch can be connected directly to 24V through a normally open switch or contact. A Form C contact can be used for improved noise immunity; connect the normally closed contact to 0V.


**Figure 52 - EMD Safety Relay - Jog**



**SI Safety Relay**  
**(Cat. No. 440R-S12R2)**

The SI safety relay monitors a gate interlock with mechanical contacts in the following image. The SI safety relay is configured for automatic reset. When the gate is closed, the SI safety relay outputs turn on if contactors K1 and K2 are already off. Press the Start button to turn on contactors K1 and K2.

**Figure 53 - SI Safety Relay Example**





## Ethernet Communication

The DI, DIS, EM, EMD, and SI safety relays are equipped with optical communication via an optical link. With an optical link, diagnostic data can be read from these safety relays and transferred to other devices over EtherNet/IP™ with the catalog number 440R-ENETR EtherNet/IP module. The CI safety relay does not have an optical link.

As shown in the following image, the catalog number 440R-ENETR EtherNet/IP module must be in the leftmost position. See publication [440R-UM009](#) for more details on the EtherNet/IP module. The safety relays must be Series A 200 or later.

**Figure 54 - Arrangement of EtherNet/IP Module and Safety Relays**




## Webpage

The catalog number 440R-ENETR EtherNet/IP module maintains its own webpage (see the following image). To access the webpage, connect an Ethernet cable to your computer, open a web browser, and type in the IP address of the ENETR module.

The webpage is only available with the 440R-ENETR Series A. The webpage is not available in Series B or later.

**Figure 55 - ENETR Webpage**




# Studio 5000 Logix Designer Add-on Profile (AOP)

The catalog number 440R-ENETR EtherNet/IP module includes the Studio 5000 Logix Designer® AOP for the DI, DIS, EM, EMD, and SI safety relays. The AOP allows you to view the status of the safety relays, including open and closed inputs, outputs on and off, waiting for reset, and fault information. The following image shows an example of the AOP for the DI safety relay.

See publication [440R-UM009](#) for further details on the EtherNet/IP module.

Figure 56 - AOP for the DI Safety Relay



## Troubleshooting

This chapter explains a systematic approach to determine the likely cause of the GSR safety relay being in a faulted state or not operating properly. It describes the procedures to use to troubleshoot your safety relay.


### Tools Needed

To troubleshoot your GSR safety relay, you need the following tools.

#### Required Tools

- Medium-sized screwdriver: For terminal screws, to remove terminal blocks, and to configure the switches on the front face of the safety relays.

Figure 57 - Screwdriver [mm (in.)]



- Digital multimeter: To measure signal levels and contact resistance.


#### Optional Tools

- Oscilloscope: Dual or four-channel storage scope to view input and output signals and to capture noise transients.
- Metal paper clips: To insert into the terminals and allow connection of scope probes to terminals.

### Follow These Steps

To diagnose the condition of the GSR safety relay, follow the steps in the following image.

Figure 58 - Troubleshooting Flowchart



View the PWR/Fault Status Indicator (Step 1)

The first troubleshooting step is to examine the PWR/Fault status indicator on the front of your GSR safety relay module. See the following image for status indicator location.



 The PWR/Fault status indicator is in the same position on all GSR safety relay modules.

Figure 59 - PWR/Fault Status Indicator



The PWR/Fault status indicator has five possible states.

Status	Description	Action
Off	No power to the safety relay	Apply power
Steady green	The safety relay is in the run state	None
Steady red	The safety relay is in a nonrecoverable faulted state	See <a href="#">Table 11</a>
Flashing red	A nonrecoverable/recoverable faulted state	See <a href="#">Table 12 on page 51</a>
Green and flashing red	A recoverable faulted state	See <a href="#">Table 13 on page 52</a>

**IMPORTANT** For accurate diagnostics, always start counting the flashes after the first pause. The first cycle can be inaccurate.

Table 11 - PWR/Fault Status Indicator Is Steady Red

Status Indicator	Description	Model	Possible Causes	Corrective Action
Steady red	Faults that are not described in <a href="#">Table 12 on page 51</a> and <a href="#">Table 13 on page 52</a> result in a steady red status indicator.	All	<ul style="list-style-type: none"><li>A momentary power interruption.</li><li>Noise on the power or signal wires.</li></ul>	<ul style="list-style-type: none"><li>Cycle power to clear the fault and return the GSR safety relay to an operational state.</li><li>Reconfigure the safety relay (see <a href="#">Configuration on page 27</a>).</li><li>See additional information in <a href="#">Verify Grounding at the Power Supply on page 52</a>.</li></ul>
		CI, DI, DIS, and SI	Short circuit has occurred, or is present, from +24V DC (A1) to S11 or S21 or from 24V Common (A2) to S11 or S21.	
		DIS	Short circuit has occurred, or is present, from +24V DC (A1) to 14 or 24.	
		SI	Excessive capacitance from input wiring to ground, but not enough to cause flashing red four times.	

Table 12 - PWR/Fault Status Indicator Is Flashing Red

Status Indicator	Description	Model	Possible Causes	Corrective Action
Flashing red 1 Hz	The GSR safety relay is in Configuration mode.	All	<ul style="list-style-type: none"> <li>The safety relay is shipped from the factory with no configuration.</li> <li>The configuration process was not completed successfully.</li> </ul>	Continue with the configuration process. Rotate the switches to the desired positions and cycle power.
Flashing red 2 times	Invalid configuration.	All	<ul style="list-style-type: none"> <li>Rotary switch setting in EEPROM corrupted.</li> <li>Connections at S11 and S21 were swapped after configuration.</li> </ul>	Reconfigure the safety relay.
Flashing red 3 times	Invalid configuration.	DI, DIS	<ul style="list-style-type: none"> <li>During configuration, the Logic switch is set for IN1 OR IN2 (position 1, 3, 5, or 7), but the inputs are wired for safety mats.</li> <li>If the inputs are not closed during configuration, the DI and DIS safety relays show this fault on the next power cycle if the inputs are closed.</li> </ul>	<ul style="list-style-type: none"> <li>Reconfigure the safety relays for IN1 AND IN2 (position 2, 4, 6, or 8). See <a href="#">Configuration on page 27</a>.</li> <li>See additional information in <a href="#">Safety Mats on page 17</a>.</li> </ul>
		EMD	A jumper was added from B1 to B2 after configuration and power was later cycled.	
Flashing red 4 times	Cross fault.	All	<ul style="list-style-type: none"> <li>You modified the wiring after configuration.</li> <li>You wired up one or more input connections as a safety mat. When you stepped on the safety mat, the GSR safety relay went to Fault mode.</li> </ul>	<ul style="list-style-type: none"> <li>Check the wiring.</li> <li>Remove the short circuit and cycle the input device, or cycle the power.</li> <li>See additional information in <a href="#">Check Voltage-free Contacts on page 54</a>.</li> </ul>
		CI, DI, DIS, and SI	<ul style="list-style-type: none"> <li>A short circuit occurred (and is no longer present) or is present from S11 to S21.</li> <li>Excessive capacitance is detected on input wiring to ground. The pulse tests waveform is distorted.</li> </ul>	
Flashing red 5 times	Output test has failed on L11.	CI and SI	<ul style="list-style-type: none"> <li>A short circuit has occurred, or is present, from +24V DC (A1) or S11 to L11.</li> <li>A short circuit has occurred, or is present, from 24V Common (A2) to L11 when L11 is on.</li> </ul>	<ul style="list-style-type: none"> <li>Correct the fault and cycle power to the GSR safety relays.</li> <li>See additional information in <a href="#">Check the Single Wire Safety Circuit (Step 4) on page 59</a>.</li> </ul>
		DI and DIS	<ul style="list-style-type: none"> <li>Short circuit from L11 to L12</li> <li>Short circuit from L11 to A1 on the next downstream safety relay.</li> <li>The 24V common connection to the downstream safety relay has temporarily disconnected.</li> <li>One of the downstream safety relays exhibited a momentary power interruption.</li> <li>For long SWS runs, L11 can pick up noise. Consider running the SWS signal in shielded cable.</li> <li>Short circuit occurred from S21 to A1 while the safety relay was operational.</li> </ul>	
Flashing red 6 times	Output test has failed on 14, 24 <sup>(1)</sup>	DIS	<ul style="list-style-type: none"> <li>External cross fault</li> <li>High capacitance load</li> </ul>	<ul style="list-style-type: none"> <li>Check wiring.</li> <li>Remove fault or move high capacitance output connections to 34, 44.</li> <li>Cycle power to clear the fault.</li> <li>See additional information in <a href="#">OSSD Outputs on page 20</a>.</li> </ul>

(1) DIS safety relays only.

Table 13 - PWR/Fault Status Indicator Is Green with Flashing Red

Status Indicator	Description	Model	Possible Causes	Corrective Action
Green with flashing red 2 times	The configuration does not agree with the EEPROM.	All (except EM)	<ul style="list-style-type: none"><li>Upon power-up, one or more of the rotary switch settings do not agree with the value that is stored in the EEPROM.</li><li>One or more of the rotary switches have changed during operation.</li></ul>	The safety relay continues to operate, and the switches can return to their original position, while powered.
Green with flashing red 3 times	B1-B2 connection.	All	B2 is connected to B1, after configuration. The fault indication occurs when the EMD output is energized. If the output is already energized, this fault will be detected on the next energization of the EMD.	<ul style="list-style-type: none"><li>Remove connection and fault is cleared automatically.</li><li>See additional information in <a href="#">EMD Expansion Safety Relay B1/B2 Inputs (Step 7) on page 69</a>.</li></ul>
Green with flashing red 4 times	Retriggerable input.	EMD	Set for non-retriggerable and Logic IN input has turned off and then back on before the time expired.	Cycle the Logic In input signal to clear the fault or let the timer expire and the fault clears automatically.
			A connection was made from terminals B1 to B2, after configuration.	Repeat the configuration process; the B1-B2 connection must be made before configuration. See additional information in <a href="#">EMD Expansion Safety Relay B1/B2 Inputs (Step 7) on page 69</a> .


Check the Power Supply (Step 2)

The second troubleshooting step is to check the supply of power to your safety relay.

Check Voltage

If the PWR/Fault status indicator is off, check the voltage by placing a digital multimeter on terminals A1 and A2 as shown in the following image.

Figure 60 - Measure Power Supply Voltage




If the voltage is not within the acceptable range, verify that the power supply, wiring, circuit breakers, and/or fuses are functioning properly.

Verify Grounding at the Power Supply

IEC 60204-1 and NFPA79 require that the 24V is supplied by a PELV-rated power supply. The 24V common must be connected to protective earth, as shown in the following image. The protective ground connection must only be in one location and is often best when closest to the power supply.

Ground loops and noise transients on the ground can cause the GSR safety relays to go into a fault state. This state is hard to capture. One method is to remove the protective grounding connection between machine ground and the 24V common temporarily. Then, wait to see if the fault does not occur (wait time varies). If the fault occurs, then the grounding scheme must be investigated further.

**Figure 61 - 24V Common to Protective Earth Connection**



IEC 60204-1 edition 5.1 (Section 6.1) allows a SELV supply to be used when a PELV is not practicable due to physical or operational conditions. NFPA79 does not allow the use of a SELV supply. If you are meeting only IEC 60204-1, you can install a separate SELV supply for your safety system and leave it ungrounded (no protective ground).

## Check Safety Device Inputs (Step 3)

This step only applies to CI, DI, DIS, and SI safety relays. Each safety relay has a status indicator for its inputs.

**Table 14 - Input Status Indicator**

IN, IN1, and IN2 Status Indicator	Status	Action
Green	Both channels are closed	Go to <a href="#">Check the Single Wire Safety Circuit (Step 4) on page 59</a> .
Off	One or both input channels are open	Continue with this section.

### IMPORTANT

The following factors affect the value that is measured at the safety relay inputs:

- Voltage-free contacts
- Pulse testing waveforms
- Capacitance
- Length of wire
- Contact resistance
- Channel sequence

The following table shows the voltage levels that are viewed on an oscilloscope versus a digital multimeter.

**Table 15 - On/Off Voltage**

Measurement Device	Turn On Voltage	Turn Off Voltage
Oscilloscope	11V	5V
Digital Multimeter	6...8V	3...4V


## Check Voltage-free Contacts

Safety devices (for example; interlock switches, E-stops, or cable pull switches) with voltage-free contacts must be connected to the pulse testing outputs. You can use a digital multimeter to measure the input levels.

### Check CI Safety Relay


1. With the device contacts open, measure the voltage at the pulse testing outputs with a digital multimeter, as shown in the following image. The voltage must be 18...19V on both pulse testing outputs of the CI safety relay.

Figure 62 - Typical Voltage Measurements of the CI Safety Relay



2. Check the voltage at each of the inputs with the device contacts closed, as shown in the following image. The values must be very close to the values measured at terminals S11 and S21.
  - a. If both channels are closed, a voltmeter must read about 19V and the IN status indicator is green. The voltage levels are approximately the same on Channel 1 (S12) and Channel 2 (S22) because the pulse testing waveforms are similar on both channels.
  - b. If only one input is above the turn on voltage level, then the IN status indicator is red.
  - c. Try cycling the input device.
  - d. If the contacts of the safety device do not operate consistently, the safety device must be replaced.

Figure 63 - Check the CI Safety Inputs with the Device Contacts Closed



3. If a significant difference in voltage levels exists, see [Capacitance Effect on page 57](#) and [Long Wire - Resistance Effect on page 57](#).

To find where the voltage drop is occurring, you have to trace the wiring of the circuit that is not achieving at least 11V as measured by an oscilloscope.



### Check DI, DIS, and SI Safety Relays


DI, DIS, and SI safety relays can also be checked in a similar fashion. The voltage of Channel 1 is lower (about 14V) than Channel 2 (about 18V). The reason for the difference in voltage levels is due to the difference in the pulse test wave forms (see [Figure 67 on page 56](#)). S11 is effectively off longer than S21.

1. Check the safety inputs with the device contacts open, as shown in the following image.




The SI safety relay does not have terminals S32 and S42.

**Figure 64 - Typical Voltage Measurements of the DI, DIS, and SI Safety Relays with Contacts Open**



2. Check the voltage at each of the inputs with the device contacts closed. The values must be very close to the values measured at terminals S11 and S21.

**Figure 65 - Typical Voltage Measurements of the DI, DIS, and SI Safety Relays with Contacts Closed**



3. If a significant difference in voltage levels exists, see [Capacitance Effect on page 57](#) and [Long Wire - Resistance Effect on page 57](#).

### Examine Pulse Test Waveforms

If you have an oscilloscope, you can examine the pulse tests. The test pulses are used to check for short-circuit conditions; the test pulses are not used to turn the inputs on and off. If they are clean and square, then they are OK.

The test pulses are generated on terminals S11 and S21. The waveforms, which are shown in the following images, must always be present on their respective safety relays; the test pulses cannot be turned off or adjusted.

Figure 66 - CI Safety Relay Pulse Test Waveforms





Figure 67 - DI, DIS, and SI Safety Relay Pulse Test Waveforms



Effect of OSSD Test Pulses

GSR safety relays cannot detect short circuits of OSSD outputs. The PWR/Fault status indicator of your GSR safety relay remains steady green. The device with the OSSD outputs must detect short circuits of its own OSSD outputs. When detected, the device must shut off both OSSD outputs and go to a faulted state. A status indicator must inform you that the OSSD is faulted. See [Devices with OSSD Output on page 16](#) for more information.

Detect Off Pulses

When configured for monitored manual (or manual) reset, the GSR safety relay detects off pulses as described in the following table.

Table 16 - Off Pulses

Time	Description
Off time ≥25 ms	GSR safety relays always detect when the input device turns off. GSR safety relays also detect that the input device has turned back on.
7 ms < Off time < 25 ms	When the off pulse is between 7...25 ms, GSR safety relays turn off their output, but the input does not turn back on. The input must be cycled again.
Off time < 7 ms	GSR safety relays cannot detect inputs that turn off for 7 ms or less.


Test pulses on OSSD outputs are less than 1 ms; therefore the GSR safety relay ignores the test pulses.

## Capacitance Effect

Capacitance leakage of the input wiring to ground causes a deformation of the leading edge of the pulses. The following image shows the deformation with 1  $\mu\text{F}$  on each signal to ground. With this high capacitance, the CI safety relay still operates.

Capacitance from Ch1 to Ch2 looks the same as Ch1 to ground and Ch2 ground.


**Figure 68 - Capacitive Effect on Pulse Tests**



## Long Wire - Resistance Effect

Long input wiring adds resistance and decreases the input signal voltage. The following image shows the effects on the pulse tests. Notice that the shape of the pulses has not changed, only the amplitude. If the wiring is too long, the safety relay does not turn on.

**Figure 69 - Resistance Effect on Input Signal**



GSR safety relays have a maximum input resistance of 900 ohms.

[Table 17 on page 58](#) shows the resistance of wire sizes that are typically used to connect to safety devices. For example, if you used 200 m (656.2 ft) of a 4-wire cable that contains 0.33  $\text{mm}^2$  (22 AWG) wire, the wire resistance from the safety relay pulse test outputs to the safety device and back to the safety relay inputs, would be:

$$200 \text{ m} \times 52.94 \, \Omega / 1000 \text{ m} \times 2 \text{ directions} = 21 \, \Omega$$

As the example shows, long wires are not a likely cause of safety input issues.


Table 17 - Wire Resistance

ISO Cross Section [mm <sup>2</sup> ]	AWG	Ω Per 1000 m	Ω Per 1000 ft
0.33	22	52.94	16.14
0.5	20	33.30	10.15
0.75	18	20.95	6.386
1.5	16	13.18	4.016
2.5	14	8.28	2.525
4	12	5.21	1.588

Channel Simultaneity (Discrepancy)

GSR safety relays have infinite simultaneity (sometimes referred to as discrepancy). One channel can close (at T1) and the other channel can close much later (at T2), and the input circuit is satisfied. The order in which the channels close is not significant; either channel can close before the other.


Figure 70 - GSR Safety Relays Have Infinite Simultaneity (Discrepancy)



Multiple-channel Cycling

GSR safety relay inputs are not satisfied if one channel turns on and off multiple times, followed by the closure of the second channel. The input status indicator remains red. This condition is not shown as a fault condition by the PWR/Fault status indicator. To clear this condition, open both channels and then reclose them.

Figure 71 - Multiple Cycles on One Channel Are Not Allowed




## Recovery Time

Recovery time is a delay time that is required, measured from when the safety relay inputs turned off until they can turn back on again. GSR safety relays have a 30 ms recovery time specification.

The GSR family of safety relays has conservative recovery time specifications. Actual measurements show the recovery time to be as fast as 20 ms. As a result, recovery time is unlikely to cause spurious trips.

Figure 72 - Recovery Time



Fast input cycling, where both input channels are cycled simultaneously, has three outcomes:

- Cycles shorter than 7 ms are ignored.
- Cycles of 7...30 ms: An input cycle causes the output to turn off. The IN1 or IN2 status indicator is off and the output is off (even with automatic reset).  
Repeated cycles of the input at less than 30 ms cause the output to be off or on, but a true state is always present. An example in automatic reset: If the inputs are green, the outputs are green, and if one of the inputs is off, the output is off.
- Cycles longer than 30 ms are processed properly.

## Check the Single Wire Safety Circuit (Step 4)

The Logic IN status indicator represents the single-wire safety (SWS) signal at terminal L12. The SWS output is terminal L11.

Check the Logic IN status indicator.

Table 18 - Logic IN Status Indicator

Logic IN Status Indicator	Status	Action
Green	L12 input is active (closed)	See <a href="#">Check the Reset/Monitoring Circuit (Step 5) on page 61</a>
Off	L12 input is inactive (open)	See <a href="#">SWS Connections L11 and L12</a>

## SWS Connections L11 and L12


CI and SI safety relays only have SWS outputs (terminal L11); they do not have SWS inputs.

DI and DIS safety relays have both SWS input and output signals. If you have a DI or DIS safety relay and the SWS input signal is not used, then the Logic IN status indicator is always off. If no wire is connected to terminal L12, then make sure that the LOGIC switch is set is to either 1, 2, 5, or 6 (switch positions with OR logic).

EM or EMD expansion safety relays have both SWS input and output signals. You must connect a wire to L12. Your application requirements determine whether L11 is used.


The following image shows an example of an SWS connection. Note the L11 terminal (which is the SWS output) can be connected to multiple L12 terminals (SWS input), but the L12 terminal cannot be connected to multiple L11 terminals.

**Figure 73 - Example SWS Connections**



For long wire runs of the SWS signal, a shielded cable can be necessary to help prevent nuisance faults from electromagnetic and motor noise.

**Figure 74 - SWS with Shielded Cable**



The following image shows the characteristics of SWS signal when it is active. It starts with a 1 ms pulse, followed 700  $\mu$ s later by a 500  $\mu$ s pulse. This waveform is repeated every 4 ms. When inactive, the SWS is 0V.

**Figure 75 - SWS Waveform**




When the signal is active, use a digital multimeter to measure the voltage. The digital multimeter shows 8...9V.

If a fault occurs with either an SWS input or SWS output, then that circuit is held high. If a digital multimeter reads a voltage measurement of approximately 21V, the signal is high. The PWR/Fault status indicator flashes red five times.

The following image shows an example timing of a momentary interruption of the SWS input. If a momentary interruption of the SWS signals occurs, the downstream unit ignores interruptions less than 5.7 ms. The downstream unit automatically turns off and then back on when the interruption is greater than 5.7 ms.

The momentary interruption does not cause a 'recovery' type fault, where the output turns off and stays off and requires a further cycling of the SWS signal.

Figure 76 - Momentary Interruption of SWS Input




## Check the Reset/Monitoring Circuit (Step 5)

The OUT status indicator flashes green when the inputs to the GSR safety relay are satisfied and the GSR safety relay is ready to turn on its outputs. The OUT status indicator flashes green at a 1 Hz rate. The GSR safety relay is waiting for the appropriate reset signal at terminal S34.

If the OUT status indicator is flashing green, but the safety relay does not turn on its outputs when the Reset button is pressed, measure the voltage at terminal S34 (point 1) as shown in the following image. If 24V is not present when the Reset button is pushed, then check the other connections (points 2...7) in the circuit. If 24V is present at terminal S34, then you must consider the reset configuration.

- Automatic/manual: The GSR safety relay must be replaced as the output status indicator must turn steady green as soon as the voltage was present at terminal S34.
- Monitored/manual: If the output status indicator does not turn steady green when voltage at S34 is present between 0.25...3 seconds, then the GSR safety relay must be replaced.

Figure 77 - Measure Reset/Monitoring Circuit Voltage



## Two-handed Reset Operation

Reset signals for GSR safety relays can be pressed 10 ms after the safety relay inputs are satisfied. Therefore, GSR safety relays are useful for application scenarios such as:


- The application has an E-stop mounted close to the Reset button, which allows you to release the E-stop with one hand and press the Reset button with the other.
- The application allows you to close a safety gate with one hand and press the Reset button with the other hand.

## Applications with OSSD Outputs and Test Pulses

If your application uses an OSSD output with test pulses as the source of the reset signal, the GSR safety relays execute the reset function properly as shown in the following image.

Test pulses are much less than 1 ms long. GSR safety relays ignore test pulses up to 6 ms in duration. Test pulses between 7...13 ms are sometimes ignored and sometimes cause the execution of the Reset function. The following image shows a reset signal that is 2500 ms long. During this time, a 6 ms test pulse occurs. This test pulse is ignored. A test pulse of 14 ms causes the GSR safety relay to execute the reset function, provided the test pulse occurs after 250 ms.

**Figure 78 - Reset Input Ignores Test Pulses Up to 6 ms**



## Check the Safety Outputs (Step 6)

The GSR family of safety relays has two types of outputs.

- Electromechanical outputs: CI, DI, EM, EMD, and SI safety relays
- OSSD outputs: DIS safety relay

## Electromechanical Output Issues

If the OUT status indicator is steady green, but the output device does not energize, begin troubleshooting by measuring the terminal voltage.


### *Measure the Terminal Voltage*

Confirm that voltage is present at the safety relay terminals and the load. The following image shows an example of the measurement points for one output channel (13/14). Since most safety circuits consist of two channels, repeat the checking on the second channel (23/24).




Step	Description
1	The voltage at I3 must be the same as the supply voltage. If not, check for an open circuit (broken wire), blown fuse, or tripped circuit breaker.
2	The voltage at I4 must be the same as the supply voltage. If not, the positive-guided safety relay inside the GSR safety relay is not closing. Measure the contact resistance; see <a href="#">Figure 80 on page 64</a> .
3	The voltage at A1 must be the same as the supply voltage. If not, check for an open circuit (broken wire) between terminal I4 and A1.
4	The voltage at A2 must be zero. If not, check for an open circuit between A1 and the voltage supply ground connection. If A2 measures zero volts and A1 measures the supply voltage, then K1 is not operating properly and must be replaced.

If the voltage at terminal 13 is the same as the supply voltage but terminal 14 measures 0V, measure the contact resistance.



The contact resistance must be less than 1 ohm. If it is not, then the internal positive-guided safety relay is not functioning properly, and the GSR safety relay must be replaced.

Figure 80 - Measure the Contact Resistance



OSSD Output Issues


If the OUT status indicator is steady green, but the output device that is connected to terminal 14 or 24 does not energize, begin troubleshooting by checking the voltage at the output connections. See [Check the OSSD Connections](#).

If the OUT status indicator is steady green, but the PowerFlex® drive indicates that the safety circuit is open, check the connections to the PowerFlex drive. See [Check the PowerFlex Drive Connections on page 65](#).

Check the OSSD Connections

Confirm that voltage is present at the safety relay terminals and the load. The following image shows an example of the measurement points for one output channel (terminal 14). Since most safety circuits consist of two channels, repeat the checking on the second channel (terminal 24).

Figure 81 - OSSD Output Connections




Step	Description
1	The voltage at 14 must be slightly less than the supply voltage. If not, then the DIS safety relay must be replaced.
2	The voltage at A1 must be slightly less than the supply voltage and must be the same voltage as measured at terminal 14. If not, check for an open circuit (broken wire) between terminal 14 and A1.
3	The voltage at A2 must be zero. If not, check for an open circuit between A1 and the voltage supply ground connection. If A2 measures zero volts and A1 measures the supply voltage, then K1 is not operating properly, and must be replaced.

### Check the PowerFlex Drive Connections

Confirm that voltage is present at the safety relay terminals and the safety input terminals of the PowerFlex drive. The following image shows an example of the measurement points for one output channel (terminal 34). Repeat the checking on the second channel (terminal 44). The terminal connections from 34 and 44 to S1 and S2 can be reversed.

**Figure 82 - Typical Connections to PowerFlex Drive**




Step	Description
1	The voltage at 34 must be slightly less than the supply voltage. If not, then the DIS safety relay must be replaced.
2	The voltage at S2 must be slightly less than the supply voltage and must be the same as the voltage at terminal 34. If not, check for an open circuit (broken wire) between terminal 34 and S2.
3	The voltage at terminal 4 must be zero. If not, check for an open circuit between terminal 4 and the voltage supply ground connection. <a href="#">Figure 83</a> shows how to verify the continuity from terminal 4 of the drive to terminal A2 of the DIS safety relay.

The following image shows the test connections to verify the common reference between the DIS safety relay and the AC Drive. Remove power from the application and set the digital multimeter to ohms. If possible, measure directly at the terminals. The resistance must be less than 1 ohm.



**SHOCK HAZARD:** Turn the power off before continuity is tested.

**Figure 83 - Continuity Test of the Voltage Supply Common Connection**



The OSSD test pulses of the DIS safety relay, as viewed by an oscilloscope, are shown in the following images. Most often, the main transistor triggers the scope; this test pulse appears on all four terminals simultaneously. The main transistor pulses are about 110  $\mu$ s wide. Each

channel is tested individually as shown in [Figure 85](#). The individual pulses are about 50  $\mu$ s wide. These pulse widths are provided for informational purposes; the pulses cannot be turned off or adjusted.

Figure 84 - OSSD Main Transistor Test Pulses





Figure 85 - OSSD Channel Transistor Test Pulse



Auxiliary Output Issues

Table 19 - Auxiliary Output Issues

State	Symptom	Action
OUT status indicator is off	My PLC does not know that the safety relay is off or my auxiliary status indicator does not turn on.	See <a href="#">Measure the Auxiliary Output Terminal Voltage on page 67</a> .
	The voltage at terminal 41 is the same as the supply voltage. However, terminal 42 measures 0V.	See <a href="#">Measure the Contact Resistance on page 67</a> .
	Terminal Y32 does not turn on.	See <a href="#">Check the Y32 Output on page 68</a> .
	Terminal X32 does not turn on.	See <a href="#">Check the X32 Output on page 69</a> .
Safety outputs are off	The Y32 output must be on. This condition is true for both faulted and running states.	See <a href="#">Check the Y32 Output on page 68</a> .




For more information on auxiliary outputs, see [Auxiliary Output on page 22](#).

### Measure the Auxiliary Output Terminal Voltage

When the OUT status indicator is off, my PLC does not know that the safety relay is off or my auxiliary status indicator does not turn on.

Confirm that voltage is present at the safety relay terminals and the load. The following image shows an example of the measurement points for one output channel (41/42).

**Figure 86 - Measure Voltage Aux Output Terminals**



Step	Description
1	The voltage at 41 must be the same as the supply voltage. If not, check for an open circuit (broken wire), blown fuse, or tripped circuit breaker.
2	The voltage at 42 must be the same as the supply voltage. If not, the positive-guided safety relay inside the GSR safety relay is not closing. Measure the contact resistance; see <a href="#">Figure 87 on page 68</a> .
3	The voltage at the PLC input must be the same as the supply voltage. If not, check for an open circuit (broken wire), a bad contact at a terminal connection), or go to step 4.
4	Place the black test probe on the PLC common terminal. Verify that the common of the PLC is connected to the common of the voltage supply.
5	The aux output voltage at one side of the auxiliary status indicator must be the same as the supply voltage. If not, check for an open circuit (broken wire) between terminal 14 and Aux status indicator.
6	Verify that the aux status indicator is connected to the voltage supply common. The aux status indicator must be replaced.

### Measure the Contact Resistance


The OUT status indicator is off, and the voltage at terminal 41 is the same as the supply voltage. However, terminal 42 measures 0V.



**SHOCK HAZARD:** Turn off power before power connection is removed if +V supply is greater than 50V.

Measure the contact resistance to confirm that the safety relay is not functioning properly. As shown in the following image, remove the power wires to terminal 41 and set the digital multimeter to ohms. Be sure that the OUT status indicator is off.


The contact resistance must be less than 1 ohm. If it is not, then the internal positive-guided safety relay is not functioning properly, and the GSR safety relay must be replaced.

**Figure 87 - Measure Contact Resistance of Aux Output Terminals**

### Check the Y32 Output

When the OUT status indicator is off, terminal Y32 does not turn on, or when the safety outputs are off, the Y32 output must be on. This condition is true for both faulted and running states.

Use a digital multimeter to measure the voltage at Y32 (point 1 in the following image). The voltage must be around 23V DC. The following image shows a typical schematic for the aux output; the aux signal can go to a PLC input or to a status indicator on a control panel. If it is 23V, then check points 2...5 in the following image. If Y32 measures 0V, then the safety relay must be replaced.

**Figure 88 - Measure Y32 Voltage**

## Check the X32 Output

When the OUT status indicator is off, terminal X32 does not turn on.




This operation is proper for the EM and EMD safety relays if they are in a nonrecoverable faulted state. If so, then the PWR/Fault status indicator is steady red or flashing red.

Correct the fault and cycle power. The safety relay must be reconfigured to correct the fault.

If the PWR/Fault status indicator is green, then measure the voltage at terminal X32 with a digital multimeter. The following image shows a typical usage of X32 (point 1) as the source for the monitoring circuit. The voltage must be around 23V DC. If it is 23V, then follow the circuit and check the voltage at points 2...6 in the following image. If X32 measures 0V, then the safety relay must be replaced.

**Figure 89 - Measure X32 Voltage**



## EMD Expansion Safety Relay B1/B2 Inputs (Step 7)


The following image shows the waveform from B1 to B2. This waveform is the same as the single wire safety waveform. The waveform is present only when the output of the EMD expansion safety relay is on. With a digital multimeter, the voltage measures 8...9V DC.

If the B1 status indicator is on, but no voltage is read, the expansion safety relay must be replaced.



For more information on retriggerable inputs, see [Retriggerable Input on page 25](#).

**Figure 90 - The B1-B2 Waveform When the EMD Safety Relay Output is On**




## Terminal Block Removal and Replacement

Terminal blocks can be replaced following these instructions.

### Terminal Block Removal

GSR safety relays have removable terminal blocks. Use a screwdriver as a lever to remove the blocks. As shown in the following image, insert the screwdriver into the slot and pry up.


Figure 91 - Terminal Block Removal



### Terminal Block Replacement

The terminal blocks are keyed to help prevent a block from being inserted into an incorrect location. The orange-colored insert provides the orientation of the key.

Figure 92 - Orange Keyway






## Series, Version, and Manufacturing Date Code

The product label differs slightly depending on when you purchased your safety relay.

### Current Product Label

The series, firmware revision number, and manufacturing date code are identified on the safety relay label, as shown in the following image.


Figure 93 - Product Label - Series and Revision Identification



### Old Product Label

The initial production runs of GSR safety relays excluded a firmware revision number, as shown in the following image.

Figure 94 - Early Version of Product Label



**Notes:**

## Specifications

### General

Attribute	440R-S13R2 (CI)	440R-D22R2 (DI)	440R-D22S2 (DIS)	440R-EM4R2 (EM)	440R-EM4R2D (EMD)	440R-S12R2 (SI)
Dimensions, HxWxD [mm (in)]	119.14 x 22.5 x 113.6 (0.88 x 4.69 x 4.47)					
Shipping weight, approx. [g (lb)]	225 (0.5)	180 (0.4)	50 (0.33)	225 (0.5)	220 (0.49)	150 (0.33)
Wire size [mm <sup>2</sup> (AWG)]	0.2...2.5 (24...14)					
Wiring category [°C (°F)]	Copper that withstands 75 (167)					
Terminal screw torque [N•m (lb•in)]	0.4 (4)					
Power supply voltage range	24V DC PELV/SELV, 0.85...1.1 x rated voltage					
Power on delay, max [s]	7					
Power consumption, typical [W]	4	3.3	2.5	2.8	2.9	2.5
Case material	Polyamide PA 6.6					
Terminal protection	IP20					
Enclosure protection	IP40 (NEMA 1)					
Mounting [mm (in)]	35 (1.38) DIN rail in enclosure that is rated to a minimum of IP54					

### Environmental

Attribute	440R-S13R2 (CI)	440R-D22R2 (DI)	440R-D22S2 (DIS)	440R-EM4R2 (EM)	440R-EM4R2D (EMD)	440R-S12R2 (SI)
Temperature, operating [°C (°F)]	-5...+55 (23...131)					
Relative humidity	90%					
Vibration	10...55 Hz, 0.35 mm (0.01 in.)					
Shock	10 g, 16 ms					
Pollution level	2					
Installation group	Overvoltage Category III, VDE 0110-1					
Impulse withstand voltage [V]	2500					

## Safety Inputs IN, IN1, and IN2

Attribute		440R-S13R2 (CI)	440R-D22R2 (DI)	440R-D22S2 (DIS)	440R-EM4R2 (EM)	440R-EM4R2D (EMD)	440R-S12R2 (SI)
Inputs		1 NC, 1 PNP (OSSD)	2 NC, 2 PNP (OSSD)	2 NC, 2 PNP (OSSD)	—	—	1 NC, 1 PNP (OSSD)
Wiring terminals		S12, S22	S12, S22, and S32, S42	S12, S22, and S32, S42	—	—	S12, S22
On voltage	Max [V]	26.4			—	—	26.4
	Min [V]	11			—	—	11
Off voltage, max [V]		5			—	—	5
Off current, max [mA]		2			—	—	2
On current, max	At 24V DC [mA]	11.0			—	—	11.0
	At 26.4V DC [mA]	11.1			—	—	11.1
Galvanic isolation: I/O from Logic		No			—	—	No
Overvoltage protection		Yes			—	—	Yes
Test out pulse	Duration [ms]	2.5	1.5, 3		—	—	1.5, 3
	Period [ms]	14	13.6		—	—	13.6
OSSD test pulse width, max [ms]		0.75			—	—	0.75
Off pulse accepted for OSSD setting without declaring the input as off, max [ms]		3.1	2.2		—	—	2.2
Recovery time, min [ms]		30			—	—	30
Reverse voltage protection		Yes			—	—	Yes
Input capacitance [nF]		10			—	—	10
Input simultaneity		Infinite			—	—	Infinite
Allowable input resistance, max [Ω]		900			—	—	900
Allowable cable capacitance, max [nF]	S11 to S21	350	160		—	—	160
	S11 to ground	350	320		—	—	320
	S21 to ground	350	320		—	—	320
Safety mat, max size [m <sup>2</sup> ]		23	35		—	—	35

## Reset Input

Attribute		440R-S13R2 (CI)	440R-D22R2 (DI)	440R-D22S2 (DIS)	440R-EM4R2 (EM)	440R-EM4R2D (EMD)	440R-S12R2 (SI)
Wiring terminal		S34			—	—	S34
On voltage	Max [V]	26.4			—	—	26.4
	Min [V]	11			—	—	11
Off voltage, max [V]		5			—	—	5
Off current, max [mA]		2			—	—	2
On current, max	At 24V DC [mA]	11.0			—	—	11.0
	At 26.4V DC [mA]	11.1			—	—	11.1
Galvanic isolation: I/O from Logic		No			—	—	No
Overvoltage protection		Yes			—	—	Yes
Input capacitance [nF]		10			—	—	10
Duration [s]		0.25...3.0			—	—	0.25...3.0

## B1 Input

Attribute		440R-S13R2 (CI)	440R-D22R2 (DI)	440R-D22S2 (DIS)	440R-EM4R2 (EM)	440R-EM4R2D (EMD)	440R-S12R2 (SI)
Wiring terminal		—	—	—	—	B1	—
On voltage	Max [V]	—	—	—	—	26.4	—
	Min [V]	—	—	—	—	11	—
Off voltage, max [V]		—	—	—	—	5	—
Off current, max [mA]		—	—	—	—	2	—
On current, max	At 24V DC [mA]	—	—	—	—	11.0	—
	At 26.4V DC [mA]	—	—	—	—	11.1	—
Galvanic isolation: I/O from Logic		—	—	—	—	No	—
Overvoltage protection		—	—	—	—	Yes	—
Input capacitance [nF]		—	—	—	—	10	—

## Safety Outputs

Attribute		440R-S13R2 (CI)	440R-D22R2 (DI)	440R-D22S2 (DIS)	440R-EM4R2 (EM)	440R-EM4R2D (EMD)	440R-S12R2 (SI)
Wiring terminal		13/14, 23/24, 33/34	13/14, 23/24	14, 24, 34, 44	13/14, 23/24, 33/34, 43/44	17/18, 27/28, 37/38, 47/48	13/14, 23/24
Output type		3 N.O.	2 N.O.	4 PNP	4 N.O.	4 N.O. delayed	2 N.O.
Thermic current $I_{th}$ [A]		1 x 6		—	1 x 6		
Fuses output (external) [A]	Slow blow	6	—	—	6		
	Quick blow	10			10		
Switched current, min [mA]		10	—	—	10		
Switched voltage, min [V]		10	—	—	10		
Mechanical life		10,000,000 cycles		—	10,000,000 cycles		
Rating		<ul style="list-style-type: none"> <li>UL: 2 x C300</li> <li>AC-15: 1.5 A / 250V AC</li> <li>DC13: 2 A / 24V DC (0.1 Hz)</li> </ul>	<ul style="list-style-type: none"> <li>UL: 2 x C300</li> <li>AC-15: 3 A / 250V AC</li> <li>DC13: 4 A / 24V DC (0.1 Hz)</li> </ul>	<ul style="list-style-type: none"> <li>14, 24: 1.5 A each</li> <li>34, 44: 0.5 A each</li> </ul>	<ul style="list-style-type: none"> <li>UL: 4 x C300</li> <li>AC-15: 1.5 A / 250V AC</li> <li>DC13: 2 A / 24V DC (0.1 Hz)</li> </ul>		<ul style="list-style-type: none"> <li>UL: 2 x C300</li> <li>AC-15: 1.5 A / 250V AC</li> <li>DC13: 2 A / 24V DC (0.1 Hz)</li> </ul>
Capacitance		—		14, 24: 1.6 $\mu$ F each 34, 44: 9 $\mu$ F each	—		
Contact material		AgNi	AgNi + 0.2 $\mu$ Au	—	AgNi		
Reaction time safety output [ms]	L12	—	45	40	100	45	—
	Inputs	150	35	25	—	—	150
	Mat operation		40	30			
Reaction time single wire safety output [ms]	L12	—	40	45	0	45	—
	Inputs	25	25	25	—	—	25
	Mat operation	30	30	30			30
Reaction time to jog, max [ms]	B1	—	—	—	—	35	—
Response time safety output [ms]	L12	45	45	45	45	45	45
	Inputs	35	35	25	—	—	35
	Mat operation	45	45	35			45
Response time single wire safety output [ms]	L12	45	45	45	45	45	45
	Inputs	25	25	25	—	—	25
	Mat operation	40	35	35			35
	Single-wire fault	55	50	50	(1)	45	50
Response time to jog, max [ms]	B1	—	—	—	—	35	—

(1) Response time of the single-wire source device.

## Auxiliary Output

Attribute	440R-S13R2 (CI)	440R-D22R2 (DI)	440R-D22S2 (DIS)	440R-EM4R2 (EM)	440R-EM4R2D (EMD)	440R-S12R2 (SI)
Wiring terminal	—	Y32		X32		Y32
Output type	1 N.C.	1 PNP, 50 mA max				

## Single Wire Safety (SWS)

Attribute		440R-S13R2 (CI)	440R-D22R2 (DI)	440R-D22S2 (DIS)	440R-EM4R2 (EM)	440R-EM4R2D (EMD)	440R-S12R2 (SI)
Wiring terminal	Output	L11					
	Input	L12					
Continuous output current, max [mA]		50					
On state voltage drop (P/S to +), max [V]		0.2					
Surge output current, max [mA]		700					
Surge output current duration, max [ms]		5					
Load capacitance, max [μF]		1					
Off state leakage current, max [mA]		< 0.1					
Short circuit detection		No					
Short circuit protection		Yes					
Galvanic isolation: I/O from Logic		No					
Fanout (max number of connections to L11)		10			Repeater <sup>(1)</sup>	10	
Cable length between L11 and L12 [m]		30				30	

(1) The EM safety relay has a direct connection from L12 to L11, so it cannot fan out to 10 additional devices. It repeats the signal. The EM safety relay must be included as one of the fan-out units.

## Regulatory Approvals

### Agency Certifications

- UL Listed Industrial Control Equipment, certified for US and Canada.
- CE Marked for all applicable EU directives
- UKCA Marked for all applicable regulations
- C-Tick Marked for all applicable acts
- CCC Mark
- S-Mark

### Declaration of Conformity

#### CE Conformity

This product is designed and tested to meet the 2014/30/EU EMC Directive and the European Council Directive 2006/42/EC on machinery. These products also conform to:

- EN 61000-6-4: Generic Standards - Emission Standard for Industrial Environments
- EN 61000-6-2: Generic Standards - Immunity for Industrial Environments
- IEC/EN 61508 - Functional safety of electrical/electronic/programmable electronic safety-related systems
- IEC/EN 62061 - Safety of machinery - Functional safety of safety-related electrical, electronic, and programmable electronic control systems
- EN ISO 13849-1 - Safety of machinery -- Safety-related parts of control systems -- Part 1: General principles for design

This product is intended for use in an industrial environment.

For a comprehensive CE certificate visit: [rok.auto/certifications](http://rok.auto/certifications).

#### UKCA Conformity

This product is designed and tested to meet the 2016 No. 1091 Electromagnetic Compatibility Regulations and the 2008 No. 1597 Supply of Machinery (Safety) Regulations on machinery. These products also conform to:

- EN 61000-6-4: Generic Standards - Emission Standard for Industrial Environments
- EN 61000-6-2: Generic Standards - Immunity for Industrial Environments
- IEC/EN 61508 - Functional safety of electrical/electronic/programmable electronic safety-related systems
- IEC/EN 62061 - Safety of machinery - Functional safety of safety-related electrical, electronic, and programmable electronic control systems
- EN ISO 13849-1 - Safety of machinery -- Safety-related parts of control systems -- Part 1: General principles for design

This product is intended for use in an industrial environment.

For a comprehensive UKCA certificate visit: [rok.auto/certifications](http://rok.auto/certifications).

## Machine Safety Directive

The performance of the safety function is dependent on the structure of all devices that comprise the safety function. [Table 20](#) and [Table 21](#) provide the data that must be used to represent safety relays when calculating the safety integrity level (SIL) or the Performance Level (PL).

Safety relays can be used in safety circuits according to DIN EN 60204-1/VDE 0113 part 1. The following safety requirements are achievable in maximum based on the operation mode and wiring.

Specifications are applicable only if the safety function is demanded at least once within 6 months. All diagnostic tests are conducted at least before next demand. At mission time (TM), the proof test interval (PTI) is assumed. Components failure rates are according to SN29500.

### SIL Rating

Safety relays meet the requirements in the following table in accordance with IEC/EN 61508 and can be used in applications up to SIL 3 according to IEC 62061.

**Table 20 - SIL Rating**

Attribute	440R-S13R2 (CI)	440R-D22R2 (DI)	440R-D22S2 (DIS)	440R-EM4R2 (EM)	440R-EM4R2D (EMD)	440R-S12R2 (SI)
PFH (1/h)	4.39 E-09	4.49 E-09	4.39 E-09	1.52 E-09	4.55 E-09	3.98 E-09
Safety integrity level	3					
Mode of operation	High demand					
Hardware fault tolerance	1					
Safe failure fraction	99%					

### Performance Level/Category

Safety relays can be used in safety systems that meet up to Category 4 and Performance Level PL<sub>e</sub> in accordance with ISO 13849-1.

**Table 21 - Performance Level/Category**

Attribute	440R-S13R2 (CI)	440R-D22R2 (DI)	440R-D22S2 (DIS)	440R-EM4R2 (EM)	440R-EM4R2D (EMD)	440R-S12R2 (SI)
MTTFd	252	230	439	342	256	363
Category	Up to 4					
Performance Level	Up to e					
DC avg	98.8%					
Mission time [year]	20					
Days of operation	365					
Hours of operation	24					
T cycle	8 hr/8.28 s					



## A

- add-on profile**
  - Studio 5000 Logix Designer 48
- adjustment**
  - switch 27
- agency certifications** 77
- AOP**
  - Studio 5000 Logix Designer 48
- application**
  - examples 41
    - CI safety relay 41
    - DI safety relay 42
    - DIS safety relay 43
    - EM safety relay 44
    - EMD safety relay 44
    - SI safety relay 46
- approvals**
  - regulatory 77
- assignments**
  - terminal 13
- automatic**
  - reset 23
- auxiliary output** 22, 67
  - issues 66
  - specifications 76

## B

- BI input**
  - specifications 75

## C

- capacitance effect** 57
- category** 78
- CE conformity** 77
- certifications**
  - agency 77
- channel simultaneity** 58
- check**
  - power supply 52
  - safety device input 53
  - safety output 62
  - single wire safety circuit 59
  - voltage 52
- CI safety relay**
  - overview 10
- circuit block diagram** 39, 40
- communication**
  - Ethernet 47
- compliance**
  - European Union (EU) directives 77
- configuration** 27
  - process 29
- connect**
  - power supply 15
- considerations**
  - enclosure 12

## contact

- resistance 67
- voltage-free 54

## cycling

- multiple-channel 58

## D

- date code**
  - manufacturing 71
- detect**
  - off pulse 56
- devices**
  - mechanical contacts 15
  - safety, OSSD output 16
- DI safety relay**
  - overview 10
  - safety mat 42
  - switch adjustment 28
- diagnostics**
  - indicators 31
- diagram**
  - internal circuit block 39
    - CI safety relay 39
    - DI safety relay 39
    - DIS safety relay 39
    - EM safety relay 39
    - EMD safety relay 40
    - SI safety relay 40
- dimensions**
  - mounting 11
- DIN rail** 11
  - mounting 11
  - removal 11
- directive**
  - European Union 77
- DIS safety relay**
  - overview 10
  - switch adjustment 28
- discrepancy** 58

## E

- effect**
  - OSSD test pulse 56
- electromechanical**
  - output 20
- electromechanical output**
  - issues 62
- EM safety relay**
  - overview 10
- EMD safety relay**
  - overview 10
  - switch adjustment 28
  - timing functions 35
- enclosure**
  - considerations 12
- environmental**
  - specifications 73
- Ethernet**
  - communication 47

**European Union (EU) directives**

compliance 77

**examples**

application 41

CI safety relay 41

DI safety relay 42

DIS safety relay 43

EM safety relay 44

EMD safety relay 44

SI safety relay 46

wiring 41

CI safety relay 41

DI safety relay 42

DIS safety relay 43

EM safety relay 44

EMD safety relay 44

SI safety relay 46

**excessive heat**

prevent 12

**expansion relays**

monitor 24

**F****features**

hardware 9

**functions**

pulse testing 33

**G****general**

specifications 73

**ground** 13, 52

relay 14

**Guardmaster safety relay**

CI 10, 39, 41

DI 10, 28, 39, 42

DIS 10, 28, 39, 43

EM 10, 39, 44

EMD 10, 28, 35, 40, 44

SI 10, 40, 46

**H****hardware**

features 9

**heat**

prevent excessive 12

**I****indicator**

PWR/fault 50

flashing red 51

green with flashing red 52

solid red 50

**indicators**

diagnostics 31

normal operation 31

powerup 31

status 31

**input**

jog 25

monitor 22

pulse testing 33

CI safety relay 33

DI, DIS, and SI safety relay 34

reset 22

retriggerable 25

safety 15

single wire safety 21

SWS 21

**installation** 11**internal circuit block**

diagram 39

CI safety relay 39

DI safety relay 39

DIS safety relay 39

EM safety relay 39

EMD safety relay 40

SI safety relay 40

**J****jog** 37

input 25

**L****label**

product (current) 71

product (old) 71

**long wire** 57**M****machine safety directive** 78**manual**

reset 23

**manufacturing date code** 71**mats**

safety 17

**mechanical contacts**

devices 15

**monitor**

expansion relays 24

input 22

**monitored reset** 23**mounting**

dimensions 11

DIN rail 11

**multiple-channel**

cycling 58

**multi-position**

switch 9

**N****non-retriggerable**

off delay 35

**normal operation**

indicators 31

## O

- off delay**
  - non-retriggerable 35
  - retriggerable 36
- off pulse**
  - detect 56
- on delay** 36
- optical communication bus** 10
- OSSD output** 20
  - issues 64
  - safety devices 16
- OSSD outputs**
  - pulse testing 34
- OSSD test pulse**
  - effect 56
- output**
  - auxiliary 22, 67
    - issues 66
  - electromechanical 20
  - OSSD 20
  - safety 19
  - single wire safety 21
  - SWS 21
  - X32 69
- overview** 9
  - CI safety relay 10
  - DI safety relay 10
  - DIS safety relay 10
  - EM safety relay 10
  - EMD safety relay 10
  - SI safety relay 10

## P

- performance level** 78
- power** 13
- power supply**
  - check 52
  - connect 15
  - ground 52
- powerup**
  - indicators 31
- prevent**
  - excessive heat 12
- process**
  - configuration 29
- product label**
  - current 71
  - old 71
- pulse testing**
  - functions 33
  - input 33
    - CI safety relay 33
    - DI, DIS, and SI safety relay 34
  - OSSD outputs 34
- PWR/fault status indicator** 50
  - flashing red 51
  - green with flashing red 52
  - solid red 50

## R

- rating**
  - SIL 78

- recommendation**
  - wiring 13
- recovery time** 59
- regulatory approvals** 77
- relay**
  - ground 14
- removable**
  - terminals 12
  - terminal blocks 9
- removal** 11
  - terminal block 70
- replacement**
  - terminal block 70
- requirements**
  - wiring 13
- terminals**
  - removable 12
- reset**
  - automatic 23
  - input 22
  - input, specifications 74
  - manual 23
  - monitored 23
- resistance**
  - contact 67
- resistance effect** 57
- retriggerable**
  - input 25
  - off delay 36

## S

- safety**
  - input 15
  - mats 17
  - output 19
- safety device input**
  - check 53
- safety inputs IN, IN1, and IN2**
  - specifications 74
- safety mat**
  - DI safety relay 42
- safety output**
  - check 62
  - electromechanical output
    - issues 62
  - OSSD output
    - issues 64
- safety outputs**
  - specifications 75
- safety relay**
  - CI 10, 39, 41
  - DI 10, 28, 39, 42
  - DIS 10, 28, 39, 43
  - EM 10, 39, 44
  - EMD 10, 28, 35, 40, 44
  - SI 10, 40, 46
- series** 71
- SI safety relay**
  - overview 10
- SIL**
  - rating 78
- simultaneity**
  - channel 58

**single wire safety**

- input 21
- output 21
- specifications 76

**single wire safety circuit**

- check 59

**spacing 11****specifications 73**

- auxiliary output 76
- B1 input 75
- environmental 73
- general 73
- reset input 74
- safety inputs IN, IN1, and IN2 74
- safety outputs 75
- single wire safety 76
- SWS 76

**status indicator**

- PWR/fault 50
  - flashing red 51
  - green with flashing red 52
  - solid red 50

**status indicators 9, 31**

- diagnostics 31
- normal operation 31
- powerup 31

**steps**

- troubleshooting 49

**Studio 5000 Logix Designer**

- add-on profile (AOP) 48

**suppressors**

- surge 21

**surge suppressors 21****switch**

- adjustment 27
  - DI safety relay 28
  - DIS safety relays 28
  - EMD safety relay 28
- multi-position 9

**SWS**

- input 21
- output 21
- specifications 76

**SWS circuit**

- check 59

**T****terminal**

- assignments 13
- torque 13

**terminal block**

- removal 70
- replacement 70

**terminal blocks**

- removable 9

**time**

- recovery 59

**timing functions**

- EMD safety relay 35

**tools 49****torque**

- terminal 13

**troubleshooting 31**

- steps 49

**U****UKCA conformity 77****V****version 71****voltage**

- check 52

**voltage-free contact 54****W****web page 47****wire 13**

- size 13

**wiring**

- examples 41
  - CI safety relay 41
  - DI safety relay 42
  - DIS safety relay 43
  - EM safety relay 44
  - EMD safety relay 44
  - SI safety relay 46
- recommendation 13
- requirements 13

**X****X32 output 69**

**Notes:**

# Rockwell Automation Support

Use these resources to access support information.

Technical Support Center	Find help with how-to videos, FAQs, chat, user forums, Knowledgebase, and product notification updates.	<a href="http://rok.auto/support">rok.auto/support</a>
Local Technical Support Phone Numbers	Locate the telephone number for your country.	<a href="http://rok.auto/phonesupport">rok.auto/phonesupport</a>
Technical Documentation Center	Quickly access and download technical specifications, installation instructions, and user manuals.	<a href="http://rok.auto/techdocs">rok.auto/techdocs</a>
Literature Library	Find installation instructions, manuals, brochures, and technical data publications.	<a href="http://rok.auto/literature">rok.auto/literature</a>
Product Compatibility and Download Center (PCDC)	Download firmware, associated files (such as AOP, EDS, and DTM), and access product release notes.	<a href="http://rok.auto/pcdc">rok.auto/pcdc</a>

## Documentation Feedback

Your comments help us serve your documentation needs better. If you have any suggestions on how to improve our content, complete the form at [rok.auto/docfeedback](http://rok.auto/docfeedback).

## Waste Electrical and Electronic Equipment (WEEE)



At the end of life, this equipment should be collected separately from any unsorted municipal waste.





Rockwell Automation maintains current product environmental compliance information on its website at [rok.auto/pec](http://rok.auto/pec).

Allen-Bradley, Atlas, Cadet, Elf, expanding human possibility, Ferrogard, Guardmaster, GuardShield, Kinetix, Lifeline, PowerFlex, Rockwell Automation, Rotacam, Safedge, SafeZone, SensaGuard, Sipa, Studio 5000 Logix Designer, and Trojan are trademarks of Rockwell Automation, Inc.

EtherNet/IP is a trademark of ODVA, Inc.

Trademarks not belonging to Rockwell Automation are property of their respective companies.

Rockwell Otomasyon Ticaret A.Ş. Kar Plaza İş Merkezi E Blok Kat:6 34752, İçerenköy, İstanbul, Tel: +90 (216) 5698400 EEE Yönetmeliğine Uygundur

Connect with us.    

**rockwellautomation.com** — expanding **human possibility**<sup>®</sup>

AMERICAS: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204-2496 USA, Tel: (1) 414.382.2000

EUROPE/MIDDLE EAST/AFRICA: Rockwell Automation NV, Pegasus Park, De Kleetlaan 12a, 1831 Diegem, Belgium, Tel: (32) 2663 0600

ASIA PACIFIC: Rockwell Automation SEA Pte Ltd, 2 Corporation Road, #04-05, Main Lobby, Corporation Place, Singapore 618494, Tel: (65) 6510 6608

UNITED KINGDOM: Rockwell Automation Ltd., Pitfield, Kiln Farm, Milton Keynes, MK11 3DR, United Kingdom, Tel: (44)(1908) 838-800

Publication 440R-UM0131-EN-P - July 2024

Supersedes Publication 440R-UM0131H-EN-P - February 2024

Copyright © 2024 Rockwell Automation, Inc. All rights reserved. Printed in the U.S.A.